

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI -110001

No. F.6/DFS/MS/2025/SZ/ 491
To

Dated: 10 / 10 / 2025

The Chief Security Officer,
IFCI Limited, IFCI Tower,
61, Nehru Place, New Delhi-110019

Sub: Regarding renewal of FSC in r/o IFCI Car Parking, Plot No 1, Nehru Place, New Delhi.


Sir,

This has reference with letter no IFCI/Security/FSC/IFCI/Car parking/2025 dated 02/09/2025 received through outdoor diary no 5611 dated 04/09/2025 on the subject cited above. In this connection, this is to inform you that the above-mentioned premise was visited by the officer concerned of this department on 24.09.2025 in the presence of Mr. Omprakash Verma to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. Smoke Management System (exhaust fan) not working.

In view of above Shortcomings, the application for issuance Fire Safety Certificate **is rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(A. K. MALIK)
Dy. CFO (SOUTH ZONE)
o/c DELHI FIRE SERVICE
@

Copy to: -

1. The Executive Engineer, (Bldg Department) HQ, MCD, Civic Center, Minto Road, New Delhi 110002.