

CLAS

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI -110001**

No. F.6/DFS/MS/2025/SZ/375

Dated: 11 / 08 / 2025

To

The Associate Director (Estate/Service)  
IFCI Limited, IFCI Tower,  
61, Nehru Place, New Delhi-110019

Sub: Regarding renewal of FSC in r/o IFCI Car Parking, Plot No 1, Nehru Place, New Delhi.

Sir,

This has reference with letter no IFCI/Security/FSC/IFCI/Car parking/2025/250605010 dated 06/06/2025 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 15.07.2025 in the presence of Mr. Babit Lal to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. The self closing device at Fire check door is found removed.
2. Smoke Management System found removed at some places.
3. MOEFA not working.
4. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(VIRENDRA SINGH)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

Copy to: -

1. The Executive Engineer, (Bldg Department) HQ, MCD, Civic Center, Minto Road, New Delhi 110002.