

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001


No. F6/DFS/MS/Stadium /NDZ/2025/ 520

Dated: 25/9/2025

FIRE SAFETY CERTIFICATE

Certified that the Indira Gandhi Stadium Sports Complex i.e KD Jhadav/ wrestling(Gr. + 02 upper floor), gymnastic(gr.+02 upper floor) and velodrome(tunnel + ground + one floor), was earlier granted FSC by this department vide letter no. F6/DFS/MS/Stadium/NDZ/2022/352 dated 05/08/2022. Now, the said premises was re-inspected by the officer concerned of this department on 17-09-2025 in the presence of Mr. Rohit , AE(E) and found that the said premises has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the said premises is fit for occupancy class (Assembly Building) with effect from ...25/09/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...25/09/25 at New Delhi by.


(Virendra Singh)
Chief Fire Officer

Copy to:-

1. The Commissioner, MCD, Civic Centre, New Delhi.
2. The Executive Engineer (E) DED -202, CPWD IG Stadium, New Delhi.
3. Administrator, Sport Authority of India, IGI Stadium Complex, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
3. The trained firefighting staff should be available round the clock.
4. Any deviation w.r.t. construction, seating arrangements/exits , lifts, electrical installation etc. shall be verified/checked by the concerned authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape such as exits, corridor, etc. shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any flammable material for interior decoration shall strictly be prohibited.

INSPECTION REPORT

1. Name & address of the building: Indira Gandhi Stadium at Indraprastha Estate, New Delhi
 2. Type of occupancy:- Assembly
 3. Type of case:- Renewal
 4. Details of previous FSC:- F6/DFS/MS/Stadium/NDZ/2022/352 dated 05/08/2022
 5. Fire safety directives No.- N/A
 6. Date of inspection:- 17/09/2025
 7. Name of the inspecting officer:- Sh. Ravinder Singh (DO)
 8. Name & designation of officer:
From the building side:- Mr. Rohit, AE(E)
 9. Year of construction:- Old building renovated in 2010.
 10. Applicant's letter No:- 24(02)EE(E)/DED-202/2025/773 dated 01/09/25
- There are three separate block in the stadium complex i.e KD Jhadhav/Wrestling (G+ 2), gymnastic (G+2) and Velodrome (tunnel , G+01).

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements as per previous inspection	Provided at site	Remarks MR/NM R
1.	Access to Building			
	1) Road width	12 mtr.	Main road	MR
	2) Gate width	6 mtr.	12 mtr.	MR
	3) Width of internal road	6 mtr.	6 mtr.	MR
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	08 Nos. & 2 ramp	Provided	MR
	A. KD Jhadhav/wrestling	12 nos.	Provided	MR
	B. Gymnastic	07 nos & 02 ramp	Provided	MR
	C. Velodrome			
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	2 of 2.0 mtr. & 6 of 122cm-132cm	Provided	MR
	A. KD Jhadhav/wrestling	1.5 mtr.	Provided	MR
	B. Gymnastic	1.65 mtr.	Provided	MR
	C. Velodrome			
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	2 mtr.	2 mtr.	MR
	F. Door size	2 mtr.	2 mtr.	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	Required	Provided	MR
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	1) Total numbers	180 Nos. (KD Jhadhav/wrestling)	Provided	MR

		212 nos.(gymnastic) 200 nos.(Velodrome)		
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number	28nos.(KDJhadhav/wrestling) 32 nos. (gymnastic) 20 nos.(Velodrome)	Provided	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors Smoke	Required	Provided	MR
	2) Location of main panel	Ground floor	Provided	MR
	3) Location of repeater panel	Required	Provided	MR
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	At each floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			
	1) Size of riser/down-comer	150 mm.	150 mm.	MR
	2) total Number of hydrants	28 nos (KDJhadhav/wrestling) 32 nos.(gymnastic) 20 nos. (Velodrome)	Provided	MR
	3) Hose box	28 nos. (KDJhadhav/wrestling) 24 nos. (gymnastic) 10 nos. (Velodrome)	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	43nos	Provided	MR
	2) Hose box	43 nos	Provided	MR
13.	Pumping Arrangement			
	1) Ground level	Required	Provided	MR
	a) Discharge of main pump	4500 LPM	4500 LPM	MR
	b) Head of main pump	88 mtr.	88 mtr.	MR
	c) Number of main pump	02 no.	02 no.	MR
	d) Jockey pump out put	280 LPM	280 LPM	MR
	e) Jockey pump head	88 mtr.	88 mtr.	MR
	f) Stand by pump output	4500 LPM	4500 LPM	MR
	g) Stand by pump head	88 mtr.	88 mtr.	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A

	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	2,00,000 ltrs.	2,00,000 ltrs.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank	N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any:.			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on of fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC (fire safety certificate) issued vide letter no. F6/DFS/MS/Stadium/NDZ/2022/352 dated 05/08/2022, under rule 35 (6) of the Delhi Fire Service Rules 2010. Accordingly, FSC is recommended for approval & DFA is put up for kind perusal and signature please.

Signature of the Inspecting Officer

Name: Ravinder Singh
Designation: DO

Date: 19/9/25
Dy. Chd. (N/A)

C.F.O.

19/9/25

Principal Director

DO (C.F.O.)

C.F.O.

C.F.O. to Sd/-

22/09/25

22/09/25