

chr

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/SZ/2025/ 579

Dated:- 02/12/2025

To

Sh. Kamruddin Ansari,
CGM (CNG & Steel Projects),
IGL Bhawan, Plot No. 4, Community Centre, Sec-9,
R.K. Puram, New Delhi-110022.

Sub: Regarding No Objection Certificate in r/o M/s Office Space for IGL Corporate office at 2nd floor, Tower G, World Trade Centre Nauroji Nagar, New Delhi.

Sir,

This has a reference to letter no. IGL/NBCC/WTC/451 dated 01/10/2025, on the subject cited above. In this regard, this is to inform you that the site was visited by the officer concerned of this department along with Sh. Akash Dy. Manager on dated 06.11.2025, to check and verify the compliance of the condition of Fire Safety Certificate in r/o lay out of interior finishing /fit out of furniture and functionality /extension of existing firefighting arrangements. During the visit the following shortcomings were observed.

1. Hydrant line found dry /without water and hydrant coupling & nozzle from hose reel was also found missing.
2. Exit signages are also not provided at conspicuous location.

In view of above, the application for issuances of no objection certificate /FSC for occupy the space at said floor is rejected. Further, the occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Encl : As above.

Yours faithfully,


(A.K. Malik)
Dy. Chief Fire Officer
Delhi fire service
OK

Copy to :

1. The Chief General Manager, NBCC of Redevelopment of Nauroji Nagar, New Delhi-29.