



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/EH/NDZ/2025/371

Dated: 11/09/2025

To,

The Manager,
Ikka Hospitality,
Property No.32, First floor, Defence Enclave,
Main Road, Shahdara, Delhi-110092.

Sub: - Regarding grant of Fire Safety Certificate in r/o Ikka Hospitality located at Property No.32, First floor, Defence Enclave, Main Road, Shahdara, Delhi-110092.

Sir,


This has a reference to your MHA portal application No. 2025080412220 dated:20.08.2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 03/09/2025 in the presence of Mr. Abhishek Chauhan (Owner) and observed that building comprised of Basement + Ground + 3 Upper floors (Restaurant running on first floor only).

Following shortcomings were observed during time of inspection:

1. Fire check doors not provided in kitchen.
2. Hose reel provided but not functional.
3. Internal hydrants provided but not functional.
4. Pump provided but not functional.
5. Overhead tank of capacity 10,000 liters provided against the requirement of 20,000 liters.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


10/9/2025
VIRENDRA SINGH
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

1. The Commissioner, MCD Civic Center, New Delhi, w.r.t.- MCD portal ID 2025080412220 dated:20.08.2025.