



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/EH/NDZ/2025/ 12

Dated: 08/01/2025

To,

The Joint Commissioner of Police (Lic.),
1st floor, Police Station Defence Colony,
New Delhi – 110024.

Subject: - Regarding grant of Fire Safety Certificate in r/o M/s Imperfecto Mehfil located at 033-036-039-047 Second floor Chandni Chowk, Delhi-110006.

Sir,

This has a reference to MHA application No. 2024121618057 dated 16/12/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 31/12/2024 in the presence of Mr. Vaibhav (Manager) and observed that building comprised of 03 Basement plus Ground plus four upper floors only and **Restaurant is located at second floor.**

Following shortcomings were observed during time of inspection in the restaurant:

1. Fire Check doors not provided.
2. Door size of 01 mtr. is provided against the requirement of 1.5 mtr.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Manager, M/s Imperfecto Mehfil located at 033-036-039-047 Second floor Chandni Chowk, Delhi-110006.