



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C/49

7/5
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/GH/SZ/2024/ 09

Dated: 03/01/2025

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Ref: elt.mcdonline application no. 2024122318316

Sub: Regarding renewal of Fire Safety Certificate in respect of **M/s Imperial Apartments** located at **GF, FF & SF, C-3 Site No. - 13, Main Ring Road, Lajpat Nagar-II, New Delhi-24.**

Sir,

With reference to the elt.mcdonline application no. 2024122318316 on the subject cited above, it is informed that the said guest house was inspected by the officer concerned of this department on. 28.12.2024 in the presence of Miss. Jazz (Manager) and following shortcoming were observed at the time of inspection.

1. Fire Check Door (FCD) found removed.
2. Hose reel found non functional.
3. CO detector system found removed.
4. Manual Operated Electrical Fire Alarm (MOEFA) system found removed.
5. Automatic Sprinkler System found non functional in basement.
6. Down comer system found non functional.
7. Fire pump found non functional.

In view of above shortcomings, the application for renewal for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

DL
30/12/24 C