



No. F6/DFS/MS/School/NDZ/2025/217

Dated: 15/04/2025

To,

The Principal,  
Imperial Public School,  
C - 73, Gali No. 09, Main Brijpuri Road,  
Old Mustafabad, Delhi – 110094.

**Subject: - Regarding grant of Fire Safety Certificate in r/o Imperial Public School located at C - 73, Gali No. 09, Main Brijpuri Road, Old Mustafabad, Delhi – 110094.**

Sir,

This has a reference to Outdoor diary No. 14030 dated 03/03/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 03/04/2025 in the presence of Mr. Shahnoor Malik (Principal) and observed that building comprised of basement (Sealed by MCD), ground plus four upper floors, Fourth floor (Closed by owner).

**Following shortcomings were observed during time of inspection:**

1. Width of corridor 1.22 meters is provided against the requirement of 1.50 meters.
2. Overhead tank of 5,000 liters capacity is provided against the requirement of 10,000 liters.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

OK DELHI FIRE SERVICE

Copy to:-

1. The Director of Education, Old Secretariat, Civil Lines, Delhi - 110054.