



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F.6/DFS/MS/EH./NDZ/2026/ 399

Dated: 28/04/2026

To,

Mr. Tehmim Malik,
M/s IMT Café and Restro Pvt. Ltd.
Plot No. 57-A, Main Johripur Road, Chaman Park,
Delhi-110094

Subject: - Regarding issuance of Fire Safety Certificate in r/o M/s IMT Café and Restro Pvt. Ltd located at Plot No. 57-A, Main Johripur Road, Chaman Park, Delhi 110094.

Sir,

This has a reference to MCD online application ID No. **2026031102692** dated 31/03/2026 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 15/04/2026 in presence of Sh. Avneesh and observed that building comprised of Stilt, Mezzanine, Ground plus two upper floors but Restaurant is running on ground floor and first floor of the building (Stilt (Parking), Mezzanine (Office) & 2nd floor (vacant)).

Following shortcomings were observed during time of inspection:

1. The two staircase width 1.25 meter and 0.75 meter are provided against the requirement of two staircase of width 1.50 meter each.
2. Door size 01 meter & 1.10 meter are provided against the requirement of two door of size 1.50 meter each.
3. First aid hose reels provided but not functional.
4. MOEFA provided but not functional.
5. Down-comer provided but not functional.
6. Terrace pump 450 lpm provided but not functional at the time of inspection.
7. Exit Signages/Lift Signages and firemen ground switch in the lift not provided.

Keeping in view of above shortcomings, the application for issuance of Fire Safety Certificate can not be considered at this stage. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


28/4/26

(Dr. S. K TOMAR)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

o/c

Copy to:-

1. The Commissioner, MCD, Dr. S.P. M. Civic Centre, Minto Road, New Delhi-110002
MCD ID No. **2026031102692**