

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**


No. F6/DFS/MS/NDZ/2025/ 494

Dated: 17/09/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Indraprastha Metro Station (Except PD area) at New Delhi comprised of ground, concourse and platform was earlier granted FSC by this department vide letter No.F6/DFS/MS/NDZ/2022/522 dated 23/11/2022. Now, the premises was re-inspected by the officer concerned of this department on 08/09/2025 in the presence of Mr. Ravinder Kaushik, Fire officer, DMRC and found that the said Metro Station has complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises except PD area is fit for occupancy class-D (Assembly Metro Railway) with effect from 17/09/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 17/09/2025 at New Delhi by.

  
16/9/2025  
(Virendra Singh)  
Chief Fire Officer

Copy to:-

1. Sh. Rajesh Aggarwal, E&M, Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi.

**Condition for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. This FSC is valid only for metro Station.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

## INSPECTION REPORT

1. Name & address of the building : , Indraprastha Merto Station New Delhi
2. Type of Occupancy : Assembly building (D7as Per NBC Part IV 2005)
3. Type of Case : Renewal
4. Details of previous FSC : No.F6/DFS/MS/NDZ//2022/522 dated 23/11/2022.
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2005/2239 dated 26/10/2015
6. Date of inspection : 08/09/2025
7. Name of the Inspecting Officer : Sh. Ravinder Singh DO/CC
8. Name and designation of Officer  
from the building side : Mr. Ravinder Kaushik, Fire officer DMRC
9. Year of Construction : 2006
10. Applicant's letter No. : DMRC/O&M/Fire/NOC/L-3/2025/08/11  
dated 12.08.2025

| S.No.     | Minimum Standards on fire Prevention and fire safety U/R 33 | Required        | Provided at site                                      | Remarks MR/NMR |
|-----------|---|-----------------|---|----------------|
| <b>1.</b> | <b>Access to Building</b>                                   |                 |   |                |
|           | 1) Road width   | 06 mtr.         | Provided  | MR             |
|           | 2) Gate width   | N/A             | N/A   | N/A            |
|           | 3) Width of internal road                                   | 6 mtr.          | Provided  | MR             |
| <b>2.</b> | <b>Number, Width Type &amp; Arrangement of Exits</b>        |                 |   |                |
|           | A. Number of staircases                                     |                 |   |                |
|           | 1. Upper floors   | Required        | Ground to Concourse - 2,<br>Concourse to Platform - 2 | MR             |
|           | 2. Basements  | N/A             | N/A   | N/A            |
|           | B. Width of staircase                                       |                 |   |                |
|           | 1. Upper floors   | 03 mtr. each    | Provided  | MR             |
|           | 2. Basements  | N/A             | N/A   | N/A            |
|           | C. Protection of exits                                      |                 |   |                |
|           | 1. Fire check door  | N/A             | N/A   | N/A            |
|           | 2. Pressurization   | N/A             | N/A   | N/A            |
|           | D. No. of continuous staircase to terrace                   | N/A             | N/A   | N/A            |
|           | E. Width of corridor  | N/A             | N/A   | N/A            |
|           | F. Door size  | N/A             | N/A   | N/A            |
| <b>3.</b> | <b>Compartmentation</b>                                     |                 |   |                |
|           | 1) Fire check door  | Required        | Provided  | MR             |
|           | 2) Sealing of electrical shafts                             | Required        | Provided  | MR             |
|           | 3) Fire rating of shaft door                                | Required        | Provided  | MR             |
|           | 4) Fire curtain   | N/A             | N/A   | N/A            |
|           | 5) Fire Dampers   | N/A             | N/A   | N/A            |
| <b>4.</b> | <b>Smoke Management System</b>                              |                 |   |                |
|           | 1) Basements  | 30 a/c per hour | N/A   | N/A            |



|            |   |                  |   |     |
|------------|---|------------------|---|-----|
|            | 2) Upper floors                                       | 12 a/c per hour  | N/A   | N/A |
| <b>5.</b>  | <b>Fire Extinguishers</b>                             |                  |   |     |
|            | 1) Total numbers                                      | 30 Nos.          | Provided  | MR  |
|            | 2) Types  | ABC & CO2        | Provided  | MR  |
|            | 3) ISI marking  | ISI              | Provided  | MR  |
| <b>6.</b>  | <b>First-Aid Hose Reel</b>                            |                  |   |     |
|            | 1) Total number of each floor                         | 2 Nos.           | 2 Nos.  | MR  |
|            | 2) Length of hose reel hose                           | 30 mtr.          | 36 mtr.   | MR  |
|            | 3) Nozzle diameter                                    | 05 mm            | 05 mm   | MR  |
| <b>7.</b>  | <b>Automatic Fire Detection &amp; Alarming System</b> |                  |   |     |
|            | 1) Type of detectors                                  | Smoke            | Provided  | MR  |
|            | 2) Location of main panel                             | Required         | Provided in station control room  | MR  |
|            | 3) Location of repeater panel                         | Required         | Provided at concourse level   | MR  |
|            | 4) Alternate source of power                          | Required         | Provided  | MR  |
|            | 5) Hooter's Location                                  | Required         | Provided at station control room & at all levels                          | MR  |
| <b>8.</b>  | <b>MOEFA</b>  | Required         | Provided  | MR  |
| <b>9.</b>  | <b>Public Address System</b>                          | Required         | Provided  | MR  |
| <b>10.</b> | <b>Automatic Sprinkler System</b>                     |                  |   |     |
|            | 1) Basement   | N/A              | N/A   | N/A |
|            | 2) Upper floors                                       | N/A              | N/A   | N/A |
|            | 3) Sprinkler above false ceiling                      | N/A              | N/A   | N/A |
| <b>11.</b> | <b>Internal Hydrants</b>                              |                  |   |     |
|            | 1) Size of riser/down-comer                           | Required 100 mm. | 100 mm.   | MR  |
|            | 2) Number of hydrants per floor                       | Required         | Provided at Ground level-1, at concourse level-1 at platform level-4 Nos. | MR  |
|            | 3) Hose box per floor                                 | Required         | 6 Nos.  | MR  |
| <b>12.</b> | <b>Yard Hydrants</b>                                  |                  |   |     |
|            | 1) Total number of hydrants                           | Required         | Provided  | MR  |
|            | 2) Hose box   | Required         | Provided  | MR  |
| <b>13.</b> | <b>Pumping Arrangement</b>                            |                  |   |     |
|            | 1) Ground level                                       |                  |   |     |
|            | a) Discharge of main pump                             | 1800 LPM         | Provided  | MR  |
|            | b) Head of main pump                                  | 70 mtr.          | Provided  | MR  |
|            | c) Number of main pump                                | 2 No.            | Provided  | MR  |
|            | d) Jockey pump out put                                | 180 LPM          | Provided  | MR  |
|            | e) Jockey pump head                                   | 70 mtr.          | Provided  | MR  |
|            | f) Stand by pump output                               | 1800 LPM         | Provided  | MR  |
|            | g) Stand by pump head                                 | 70 mtr.          | Provided  | MR  |
|            | h) Auto starting/Manual stopping                      | Required         | Provided  | MR  |
|            | 2) Terrace level                                      |                  |   |     |
|            | a) Discharge of pump                                  | N/A              | N/A   | N/A |
|            | b) Head of pump                                       | N/A              | N/A   | N/A |
|            | c) Power supply                                       | N/A              | N/A   | N/A |
|            | d) Auto starting of pump                              | N/A              | N/A   | N/A |
| <b>14.</b> | <b>Captive Water Storage for Fire Fighting</b>        |                  |   |     |
|            | 1) Under ground tank                                  | 1,00,000 ltrs.   | 1,00,000 ltrs.  | MR  |

N/6

|     |  |             |          |     |
|-----|--|-------------|----------|-----|
|     | a) Draw-off connection   | Required 01 | Provided | MR  |
|     | b) Fire service inlet  | Required    | Provided | MR  |
|     | c) Access to tank  | Required    | Provided | MR  |
|     | d) Over head tank capacity   | N/A         | N/A      | N/A |
| 15. | <b>Exit Signage.</b>   | Required    | Provided | MR  |
| 16. | <b>Provision of Lifts.</b>   |             |          |     |
|     | a) Pressurization of lift shaft  | N/A         | N/A      | N/A |
|     | b) Pressurization of lift lobby  | N/A         | N/A      | N/A |
|     | c) Communication in lift car   | Required    | Provided | MR  |
|     | d) Fireman's switch  | Required    | Provided | MR  |
|     | e) Lift signage  | Required    | Provided | MR  |
| 17. | <b>Stand by Power Supply</b>   | Required    | Provided | MR  |
| 18. | <b>Refuge Area</b>   | N/A         | N/A      | N/A |
|     | Total area location  | N/A         | N/A      | N/A |
| 19. | <b>Fire Control Room</b>   | N/A         | N/A      | N/A |
|     | a) Detector system panel   | N/A         | N/A      | N/A |
|     | b) Flow switch panel   | N/A         | N/A      | N/A |
|     | c) PA system panel   | N/A         | N/A      | N/A |
|     | d) Battery backup  | N/A         | N/A      | N/A |
|     | e) Building floor plan   | N/A         | N/A      | N/A |
| 20. | <b>Special Fire Protection System for Protection of special Risk, if any: Co<sub>2</sub> flooding system provided in HT/LT panel</b> |             |          | MR  |

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, **we may renew the FSC (fire safety certificate) issued vide letter no. No.F6/DFS/MS/NDZ//2022/522 dated 23/11/2022, under Rule 35(6) of the Delhi Fire Service Rules 2010.** Accordingly, DFA is prepared and put up for kind perusal and signature please.

Signature of the Inspecting Officer

Name :- Ravinder Singh  
Designation :- DO (CC)

Director  
10/9/25

C.F.O.

11/9/25  
12/9/2025

Principal Director

11/09/25

CFO to Secy.

12/09/25

15/9/2025

DO (CC)

20