

c/s8

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No.F6/DFS/MS/WZ/Industrial/2025/ 426

Dated: 27/08/2025

To,

The Owner/occupier,
India Wire & General Mills Pvt. Ltd.,
55A, Rama Road, Najafgarh Road Industrial Area,
New Delhi-110015.

Sub: Inspection report in r/o India Wire & General Mills Pvt. Ltd., located at 55A, Rama Road, Najafgarh Road Industrial Area, New Delhi-110015.

Sir,

With reference to your letter No. Nil dated Nil, received through outdoor dairy No. 3906 dated 18/07/2025, on the subject cited above. In this connection, it is to inform you that the said premises/building was re-inspected by the officer concerned of this department on 08/08/2025, in the presence of Sh. Ajay Kumar to check the shortcomings already issued by this department vide letter No.F6/DFS/MS/Industrial/WZ/2025/244 dated 30/05/2025. Some of the shortcomings at serial No. 5, 7, 8 & 9 have been rectified by the management.

However the remaining shortcomings are still not complied as under.

S. no.	Shortcomings	Status
1.	Pressurization is found removed in stair, lift lobbies & lift shaft.	Not Rectified
2.	Water Curtains are provided in lift cars but deluge valve found removed.	Not Rectified
3.	Smoke management system is provided but not functional.	Not Rectified
4.	Automatic fire detection and alarming systems is provided but not functional.	Not Rectified.
5.	Public address system provided but not functional.	Not Rectified
6.	Exit signage found removed at some places.	Not Rectified.
7.	Staircases doors found blocked at 1 st floor due to huge storage of paint canes.	Not Rectified.

In view of above shortcomings, the application for renewal of fire safety certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the owner/occupier.

Yours Faithfully,



Virendra Singh
Chief Fire Officer



Copy To:-

1. The Executive Engineer (Bldg.) HQ, Municipal Corporation of Delhi, 9th Floor, Civic Centre, Minto Road, New Delhi- 110002.