



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001





No F 6/DFS/MS/2025/School/WZ/ 970

Dated 08/08/2025

FIRE SAFETY CERTIFICATE

Certified that the **Indian Convent School** located at **CU- Block, Pitampura, Delhi-110088** comprised of **Ground plus First floor** was issued FSC by this department vide letter No F6/DFS/MS/WZ/2019/2115 dated 06.11.2019. The premises was re-inspected by the officer concerned of this department on 16.07.2025 in the presence of Smt. Neena Lamba (Head Mistress), and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy **Group B Educational** with effect from ...08/08/2025... for a period of three years, subject to compliance of the conditions mentioned below:

Issued on ..08/08/2025.. at New Delhi by


(Virendra Singh)
Chief Fire Officer


Copy to:-

1. The Director, Education, Government of NCT of Delhi. Old Sect. Delhi-110054
2. The Principal, Indian Convent School located at CU- Block, Pitampura, Delhi-110088.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building : Indian Convent School located at CU Block, Pitampura, Delhi- 110034.
2. Type of Occupancy : Educational
3. Building Comprised of : Ground and First Floor.
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/WZ/2019/2115 Dated- 06/11/2019
6. Fire Safety directives letter No : DOE Circular Dated 01/03/2011
7. Date of inspection : 16/07/2025
8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
9. Name and designation of officers
From the building side : Smt. Neena Lamba (Head Mistress)
10. Year of Construction : 2003
11. Applicant's letter No. : Outdoor Diary No. 3027 dated 24/06/2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE circular Dated 01/03/2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6 m	Provided	MR
	• Gate width	4.5 m	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.50 m	1.51 m & 1.41 m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	Provided	MR
	e. Width of Corridor	1.5 m	Provided	MR
	f. Door Size	1 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Naturally Ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	04 Nos.	08 Nos.	MR
	• Types	ABC/ Co2 Type	Provided	MR
	• IS marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	NA	01	NA
	• Length of hose reel hose	NA	30 m	NA
	• Nozzle diameter	NA	5 mm	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA

8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basement	NA	NA	NA
	• Ground Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	450 lpm	NA
	➤ Head of the pump	NA	40 m	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	5000 ltrs	NA
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA

	Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The management had rectified the shortcomings issued vide letter no. F6/DFS/MS/2024/WZ/School/575 dated 03/09/2024.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular dated 01/03/2011, it is recommended to renew the fire certificate issued vide letter no. F6/DFS/MS/WZ/2019/2115 dated 06/11/2019.

[Signature]
21/7/25

Signature of Inspecting Officer
Name : Rajeev Kumar Sinha
Designation : ADO/B.W.

[Signature]
DCFO/WZ

[Signature]
Principal Director

[Signature]
28/7/2025

[Signature]
Principal Director

[Signature]
Principal Director

[Signature]
28/7/25

ADO/B.W. Sr. F.P. letter is put up for signi place

[Signature]
31/7/25

[Signature]
4/8/2025

[Signature]
M S cell

DCFO/...21/7/2025
Dated...24/7/2025