



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



c/110

No. F6/DFS/MS/2025/School/ 116

Dated: 18/02/2025

To

The Principal
Indian National Public School at
D-178-179, Swaroop Nagar, Delhi-42.

Sub: - Regarding grant of fire safety certificate in r/o Indian National Public School at D-178-179, Swaroop Nagar, Delhi-110042.

Sir,

Please refer to your letter no- INPS/01/2025 dated: 28.01.2025 received in this department vide outdoor dairy no-11923 dated 28.01.2025 on the subject cited above. In this connection this is to inform you that the above mentioned school premises was inspected by the officer concerned of this department on 11.02.2025 in the presence of Smt. Indira Sharma (Principal) was also present at site to check the existing fire safety measures & means of escape measures. During inspection it has been observed that the school building is comprised of ground & first floors. The observations/ shortcomings made are as under:-

1. There is only one staircase is provided width of 92cm against the requirements of 1.50m or less and 75cm.
2. The class room's door size is provided 93cm against the requirement of 01m.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully


(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Deputy Director of Education, GNCT of Delhi, Zone-VII, District North Lucknow Road, Timarpur, Delhi – 110054.