

c/64

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F.6/DFS/MS/NDZ/2025/231

Dated 21/05/2025

To

Sh. Mohammad Yaseen,
Indian Red Cross Society,
1, Red Cross Road,
New Delhi - 110001.

Sub:- Issuance of Fire Safety Certificate in r/o Indian Red Cross Society, 1 Red Cross Road, New Delhi.

Sir,

This has reference to your Mail id no.<yaseenm@indianredcross.org>. dated 16/04/25, on the subject cited above. In this connection it is to inform that the site (A Block – B + Gr. + 05 upper floors), was inspected by the officers concerned of this department on 15/05/2025 in the presence of your self and the following shortcomings are still not complied:-

1. Alternate staircase found locked at upper floor .
2. Diesel pump found nonfunctional.
3. PA system found nonfunctional.
4. Smoke detectors found nonfunctional at some offices
5. Hose reel is found nonfunctional at terrace level.
6. Draw off connection is not accessible for fire tender, required to be shifted.
7. Fire service inlet found nonfunctional.

In view of above shortcomings, request for renewal of fire FSC is rejected. The occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully,

(Atul Garg)
DIRECTOR

01123414000

Copy to:

The Chief Architect, NDMC Palika Kendra, New Delhi.

16/5