



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/2025/SZ/ 151

Dated: 07/04/2025

To

The Assistant Engineer (E)-III,
PWD, HMED South-West,
Janakpuri Super Specialty Hospital,
C-2B, Janakpuri, New Delhi-110058

Sub: Inspection report in r/o Indira Gandhi Hospital located at Sector-9, Dwarka, New Delhi-110077

Sir,

Please refer to your letter No. 24(12)/AE(E)-III/PWD HMED SW/2024-2025/05 Dated 01/02/2025. In this connection, it is to inform you that the hospital premise was visited by the officers concerned of this department on 26/03/2025 to verify the availability & operability of fire safety arrangements in the presence of Sh. A.K. Tiwari (Operation Head-L&T) & Sh. Ravi Kumar (Project Head). During course of inspection, the shortcomings observed are as below.

1. Electrical shaft not sealed horizontally and vertically.
2. Water curtain in basement found non-functional.
3. First-aid hose-reel found non-functional and not covering entire area in basement.
4. Sprinklers in basement needs to be extended in left out area and below the duct.
5. Internal & yard hydrant found non-functional & hoses/branch missing in hose-box.
6. Exit signage found removed at some locations.
7. Pressurization of lift shaft found non-functional.
8. The required trained fire officer is not provided/appointed.

In view of above shortcomings, renewal of fire safety certificate cannot be considered at this stage. You are requested to rectify the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)
DIRECTOR

Ph. 011-23414000

cl/88

Copy to: -

1. The Deputy Secretary (Home/Fire), Govt. of NCT Delhi, Delhi Secretariat, New Delhi.
2. The Medical Director, Indira Gandhi Hospital, Sector-9, Dwarka, New Delhi-110077