



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6 /DFS/MS/School/SZ/2026/ 372

Dated: 24/04/2026

To

The Principal,
Indira Public School
C – 25/2, Gali No. 05, Mohan Baba Nagar,
Badarpur, New Delhi – 110044.

Subject: - Regarding grant of Fire Safety Certificate in r/o Indira Public School located at C – 25/2, Gali No. 05, Mohan Baba Nagar, Badarpur, New Delhi – 110044.

Sir,

This has a reference to your Outdoor Diary No. 12089 date 24.03.2026, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 02/04/2026 in the presence of Mr. Ajay Kumar Gupta (Manager) and observed that building comprised of Basement, Ground plus four upper floors, following shortcomings were observed during time of inspection:

1. Road width to approach the building is 4.0 meters wide against the requirement is 6.0 meters.
2. Two staircases of width 1.50 meters each not provided in basement and upper floors.
3. The corridor of width 1.30 meters against the requirement of 1.50 meters.
4. Door size width 1.0 meters against the requirement is 02 nos. of 1.20 meters.
5. Smoke Management System not provided in the premises.
6. First Aid Hose Reel provided but found nonfunctional.
7. MOEFA provided but found nonfunctional.
8. Terrace Level Pump is of 220 LPM against the requirement is 900 LPM.
9. Overhead tank capacity 5,000 liters provided against the requirement of 10,000 liters.
10. Exit & floors Signage's not provided at strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(A. K. Malik)
Chief Fire Officer
Delhi Fire Service
9/2