

C-4

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F6/DFS/MS/EH/2025/SZ/ 11

Dated: 08/01/2025

To,

The Joint C.P. (LIC.),  
1<sup>st</sup> floor, Police Station,  
Defense Colony, New Delhi.

**Sub: -Regarding renewal of "FSC" from fire safety point of view in r/o M/s Indisubs Foodology Private Limited at H. No. 147, IGNOU Road, Near Bus Stop, Village- Neb Sarai, South Delhi- 110068.**

Sir,

Please refer to online application ID 2024120917817 dated 13.12.2024, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the aforesaid eating house building on dated 03.01.2025 in presence of Mr. Uday Balhara (Director), to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the above said eating house/restaurant running at ground floor only in a building comprised of ground plus three upper floors (1<sup>st</sup>, 2<sup>nd</sup> & 3<sup>rd</sup> floor used for residence), and have following shortcomings: -

1. Two doors having width of 1.50 & 0.69 m found provided against requirement of two doors with width of 1.50 m each.
2. Ventilation system found not provided in restaurant.
3. Hose reels/hydrants found not provided.
4. Smoke/heat detectors found not provided.
5. MOEFA found not provided.
6. Terrace fire pump capacity of 450 LPM found not provided.
7. Overhead water storage tank capacity of 20,000 ltrs. found not provided.
8. Exit Signages found not provided.

Keeping in view of above, issuance of fire safety certificate can-not be considered at this stage. Management of the restaurant may be requested to rectify the above said shortcomings for taking further necessary action in this matter under intimation to this department and running restaurant/eating house in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to: -

1. The Owner/Occupier, o M/s Indisubs Foodology Private Limited at H. No. 147, IGNOU Road, Near Bus Stop, Village- Neb Sarai, South Delhi- 110068.