



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/2026/SZ/187

Dated: 19/05/2026

To,

Mr. Hemraj Thakur,
Indira IVF Hospital,
1/14 West Patel Nagar,
New Delhi-110008.

Sub: Inspection report from fire safety point of view in r/o Indira IVF Hospital, 1/14 West Patel Nagar, New Delhi-110008.

Ref: Office Order No. F.6/DFS/HQ/2026/494 dated 20/03/2026.

Sir,

This is with reference to the office order above regarding inspections of the hospitals building to verify compliance of fire protection measures. In this connection, it is to inform you that the said hospital building was issued notice on Form 'O' (Notice for Entry and Inspection) under section 33 (1) of the Act) by the Nominated Authority of this department and inspected on dated 30/04/2026 in the presence of Dr. Diksha Panisar. The shortcomings observed during the inspection were recorded and issued on Form 'P' (Notice for carrying out the directions of the Nominated Authority, under section 34 (1)/43(2) of the Act. The hospital building was found non-compliant of fire & life safety provisions required under the rules. Shortcomings as given below: -

1. The Staircase found obstructed with chairs and almirah.
2. Vertical shaft found opens in the staircase.
3. Hose reel at terrace floor found removed.
4. MOEFA system found non-functional.
5. The overhead water tank is interconnected with other domestic tanks and required to be segregated.
6. Temporary porta cabin has been made with occupancy at terrace need to be removed.

In view of the non-compliant status of the hospital from fire safety point of view. The Fire Safety Certificate of the hospital building issued vide letter No. 52026021301021 dated 25/03/2026 shall remain suspended till the compliance of the shortcomings.

Yours faithfully,


A.K. Malik
Chief Fire Officer
Delhi Fire Service
18/5 01C

Copy to: -

1. The MS – Nursing Home, Govt. of NCT of Delhi, DGHS (Nursing Home Cell), 3rd Floor, Delhi Govt. Dispensary Building, S-1, School Block, Shakarpur, New Delhi-110092.