



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/2025/School/WZ/ 932

Dated: 31/07/2025

FIRE SAFETY CERTIFICATE

Certified that the **Indraprashta Modern School, B-246 & 247, Rajeev Nagar, Opp, Rohini, Sector-22, Delhi-86**, comprised of ground + 03 upper floors, but school is running at **Ground + 02 upper floors only** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/2022/School/WZ/611 dated 03.06.2022**. The premises was re-inspected by the officer concerned of this department on **08.07.2025** in the presence of **Mr. Subhash Chand (Manager)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Educational "Group B"** with effect from **31/07/2025** for **ground + 02 upper floor only** a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 31/07/2025 at New Delhi by


29/7/2025
(Virendra Singh)
Chief Fire Officer

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, The Indraprashta Modern School, B-246 & 247, Rajeev Nagar, Opp, Rohini, Sector-22, Delhi-86.

Conditions for the validity of fire safety certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Ru+les/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

N/20

INSPECTION REPORT

1. Name & address of the building : Indraprastha Modern School, B-246 & 247, Rajeev Nagar, Opp, Rohini, Sector-22, Delhi-86.
2. Type of Occupancy : Educational
3. Comprised of building : Ground + 03 upper floors
4. Type of Case : Renewal (School is running at Ground + 02 upper floor only)
5. Details of Previous NOC : F.6/DFS/Ms/2022/School/WZ/611 dated 03.06.2022.
6. Fire Safety directives letter No : NBC Part-IV
7. Date of inspection : 08.07.2025
8. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
9. Name and designation of officers
From the building side : Mr. Subhash Chand (Manager)
10. Year of Construction : 2002 & 2014
11. Applicant's letter No. : Online e-mail dated 26.06.2025.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	4.5m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01nos.	02nos.	MR
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper Floor	1.5m	1.40m & 1.35m	MR(Old case)
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits			
	Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	-NA-	-NA-	-NA-
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	1.0m	1.0m	MR
3.	Compartmentation			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	• Basements	-NA-	-NA-	-NA-
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	12nos.	Provided	MR
	• Types	ABC/CO2	ABC/CO2	MR
	• ISI marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	01nos.	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-

	<ul style="list-style-type: none"> Location of Repeater Panel Alternate source of power Hooters' Location 	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground & Upper Floors Sprinkler above false ceiling 	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100mm 01nos. 01nos.	100mm 01nos. 01nos.	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	-NA- -NA-	-NA- -NA-	-NA- -NA-
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- 450lpm 40m Required Required	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- 450lpm 40 Provided Provided	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- MR MR MR MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	-NA- -NA- -NA- -NA- 10,000ltr	-NA- -NA- -NA- -NA- 10,000ltr	-NA- -NA- -NA- -NA- MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
17.	Standby power supply	-NA-	-NA-	-NA-
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	-NA- -NA-	-NA- -NA-	-NA- -NA-
19.	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel 	-NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA-

N/22

• Battery backup	-NA-	-NA-	-NA-
• Building Floor Plans	-NA-	-NA-	-NA-
20. Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2022/School/WZ/611 dated 03.06.2022 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

[Signature]
10/7/25

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO (Rohini)

DO (NW)

[Signature]
11/07/2025

[Signature]
22/07/2025

[Signature]
14/7/2025

CFO/
22/7/2025

Principal Director CFO May Sharma

[Signature]
23/07/25

[Signature]
23/7/2025

ADO (Rohini)

FT letter is put up for kind
perusal and signature please.

[Signature]
12/7/25

CFO/
29/7/2025

msell

DCFO/...203-NW
Dated...14/7/2025