

C/107

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE
CONNAUGHT PLACE: NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/ 540

Dated: 23/06/2025

To

Authorized Signatory,
Indraprastha International School,
(C/o Kanta Devi Charitable & Educational Society)
Sector-10, Dwarka, New Delhi-110075

Sub: **Regarding issuance of Fire Safety Certificate in r/o Indraprastha International School located at Sector-10, Dwarka, New Delhi.**

Sir,

Please refer to your letter No. IPIS/18/PRO/DFS/25/56 dated 26.05.2025 received in this department vide outdoor diary No. 2351 dated 02/06/2025. In this connection, it is to inform you that the school premise was re-visited by the officer concerned of this department on 14/06/2025 in the presence Sh. Shyam Sundar Prasad (PRO) to verify the compliance of shortcomings already issued by this office vide letter No. F6/DFS/MS/SZ/2024/738 dated 28/10/2024. During course of the inspection, the status of shortcomings observed is as below.

S. No.	Shortcomings issued	Present status
1.	Six-meter-wide internal road around the building found encroached/ blocked.	Not complied
2.	School activities noticed in basement. The Basement must be used as per BBL.	Not complied
3.	Smoke exhaust system found non-functional in basement.	Not complied
4.	Hose reel hose & hydrants found non-functional	Not complied
5.	Automatic sprinkler system found non-functional in basement	Not complied
6.	Terrace & ground level pumps found non-functional & main valves found closed.	Partially complied
7.	Exit signage's found removed at some places.	Complied
8.	The seating arrangement in auditorium must be as per cinematography act.	Not complied

In view of above, application for issuance of fire safety certificate cannot be considered at this state. You are advised to rectify the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)
DIRECTOR

Ph. 011-23414000

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.
2. The Dy. Director (L&I), Building Section, DDA, Vikas Sadan, INA, New Delhi.