



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/2025/School/584

Dated: 11/07/2025

To

The Principal  
 Indraprastha Public School,  
 1-A, Swaroop Nagar, Delhi-110042.

**Sub:** - Regarding issuance of fire safety certificate in r/o Indraprastha Public School located at 1-A, Swaroop Nagar, Delhi-110042.

Sir,

Please refer to your letter No. IPS/2025-26/007 dated: 25/06/2025 received in this department vide outdoor dairy no.3154 dated: 25/06/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 02.07.2025 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & 03 upper floors but school is running at ground & 02 upper floors. At the time of inspection Smt. Preeti (Teacher) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. There is only one staircase is provided width of 1.20m against the requirement of 1.50m or and additional staircase 75cm.
1. Hose reel hose is not provided.
2. Internal hydrant is not provided.
3. Terrace level fire pump capacity of 450 lpn is not provided.
4. Terrace level fire water tank capacity of 2500 ltr is not provided..
5. Exit and floor signage's is not provided at strategic locations in the school building.

Keeping in view of above, issue of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)  
 Director

Ph:-011-23414000

Copy to:-

1. The Deputy Director of Education, GNCT of Delhi, Zone-VII, District North Lucknow Road, Timarpur, Delhi - 110054.