



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/School/2025/SZ/ 892

Dated: 14 / 07 / 2025

FIRE SAFETY CERTIFICATE

Certified that the building of **Indraprastha International School** located at Sector-10, Dwarka, New Delhi-110075, comprised of Basement, Ground + 04 upper floors, was issued FSC by this department vide letter No. F6/DFS/MS/School/2021/893 dated. 29/10/2021. The premise was re-inspected by the officer concerned of this department on 03/07/2025 in the presence of Sh. Shyam Sundar Prasad (PRO), and found that the premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the school premise/building is fit for occupancy class "**Educational Group B**" (School) with effect from 14 / 07 / 2025 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 14 / 07 / 2025 at New Delhi by

(ATUL GARG)
DIRECTOR
Ph. 011-23414000

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054
2. Dr. Karuna Dahiya, Head-Administration, Indraprastha International School C/o Kanta Devi Charitable and Educational Society at Sector-10, Dwarka, New Delhi-110075

Conditions for the validity of Fire Safety Certificate: -

1. **Basement floor shall not be used for any purpose other than storage & parking as approved by this department, failing which, the FSC issued shall stand cancelled.**
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire-fighting system.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

N-42

INSPECTION REPORT

1.	Name & address of the building	Indraprastha International School located at Sector-10, Dwarka, New Delhi-110075		
2.	Type of Occupancy	Educational (Group B)		
3.	Building Comprised of	Basement, Ground + 04 upper floors		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F6/DFS/MS/School/2021/893 dated 29/10/2021		
6.	Fire Safety directives Letter No.	F.6/DFS/MS/BP/2017/School/22 Dt. 06/02/2017		
7.	Date of inspection	03/07/2025		
8.	Name of the Inspecting Officer	ADO (DWK)		
9.	Name and designation of Officer from the building side	Sh. Shyam Sundar Prasad (PRO)		
10.	Year of Construction	2003 & 2018		
11.	Applicant's letter No.	IPIS/18/PRO/DFS/25/68 dated 26/06/2025 Outdoor Diary No. 3137 dated 26/06/2025		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mtr	12 mtr	MR
	• Gate width	06 mtr	Provided	MR
	• Width of internal road	06 mtr	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	04 Nos	Provided	MR
	• Basements	05 Nos	07 Nos	MR
	b. Width of staircases			
	• Upper floors	1.5m each	2 x 1.5m & 2 x 2m (Including railing & skirting)	MR
	• Basements	1.5m & 2 mtr	1.5m each	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	04 Nos	Provided	MR
	e. Width of Corridor	1.5m	Provided	MR
	f. Door Size	1m & 1.20m at 4 th floor (Class rooms) & 1.5 to 2m in staircases	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Managements System			
	• Basements	12 ACPH	Non-functional	MR
	• Upper floors	12 ACPH	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	04 per floor	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• ISI marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	04 Nos	04 Nos	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR

7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	Smoke & Heat	N/A
	• Location of Main Panel	N/A	Ground Floor	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	Battery backup	N/A
	• Hooters' Location	N/A	Provided	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided & functional	MR
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	04 Nos	Provided & functional	MR
	• Hose Box	Required	Provided & functional	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	02 Nos	N/A
	• Hose Box	N/A	Provided	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	2280 LPM	2280 LPM	MR
	➤ Head of main pump	70m	70m	MR
	➤ Number of main pumps	One	One	MR
	➤ Jockey pump out put	180 LPM	180 LPM	MR
	➤ Jockey pump head	70m	70m	MR
	➤ Standby Pump out put	2280 LPM	2280 LPM	MR
	➤ Standby Pump Head	70m	70m	MR
	➤ Auto Starting/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	900 LPM	900 LPM	MR
	➤ Head of the pump	40 mtr	40 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water storage for firefighting			
	• Underground tank capacity	1,00,000 Ltrs	1,00,000 Ltrs	MR
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	25,000 ltr	25,000 ltr	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby Power Supply	Required	DG Set	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

N-99

19.	Fire Control Room			
	➤ Detector system panel	N/A	Provided at G level	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	Required	Provided at G level	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	Required	Manual operated Co ₂ in HT & LT Panels	MR

The fire protection systems provided in the school building were checked, tested at random and found functional at the time of inspection. The shortcomings communicated vide letter No. F.6/DFS/MS/School/2025/SZ/540 dated 23/06/2025 found complied.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety as required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/School/2021/893 dated 29/10/2021, renewal under rule 37 of Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for perusal/approval & signature please.

Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (DWK)

DO (SW)

Rel
7/7/25

C.S.
11/7/2025

Director
11/07/25
A.D.K.

Sir, F.T letter is put up for your sig. pl
Director
12/07/25