



No. F6/DFS/MS/School/SZ/2026/ 12

Dated: 20/01/2026

FIRE SAFETY CERTIFICATE

Certified that the Indopride literacy Mission (managed by Indopride Foundation (Regd.) located at L-1st, 8/498, near Budh Bazar Road, Budh bazar, Sangam Vihar, New Delhi-80, Comprised of Ground plus three upper floors was earlier issued Fire Safety Certificate vide letter No F6/DFS/MS/School/2022/SZ/1229 dated 11/11/2022. Now, the school building was re-inspected by officer concerned of this department on 00/01/2026 in presence of Mr. Sarik Khan of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service,2010 and that the school building is fit for occupancy class **Group - B "Educational Building"** with effect from 20/01/2026 for a period of three years in accordance with Rule 36 unless renewal under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010.

Issued on 20/01/2026 at New Delhi by.

A.K. Malik

Dy. Chief Fire Officer
Delhi Fire Service
O/C (W)

Copy to:-

1. The Dy. Directorate of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.
2. The Indopride literacy Mission (managed by Indopride Foundation (Regd.) located at L-1st, 8/498, near Budh Bazar Road, Budh bazar, Sangam Vihar, New Delhi-80

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. Basement shall be used as per UBBL 2016.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

01.	Name & address of the building	Indopride literacy Mission (managed by Indopride Foundation (Regd.) located at L-1 st , 8/498, near Budh Bazar Road, Budh bazar, Sangam Vihar, New Delhi-80		
02.	Building is comprised of	Ground plus three upper floors		
03.	Type of occupancy	Educational Building, Group - B		
04.	Type of case	Renewal Case		
05.	Details of previous FSC	F6/DFS/MS/School/2022/SZ/1229 dated 11/11/2022		
06.	Fire safety directives letter no.	NBC Part-IV & UBBL 2016		
07.	Date of inspection	10/01/2026		
08.	Name of the inspecting officers	Yashwant Singh Meena, ADO/BCP		
09.	Name of the designation of officer from the building side	Mrs. Sarik Khan		
10.	Year of construction	2021		
11.	Applicant's letter no.	Gmail dated 20/11/2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	As per old NOC	Provided at site	Remarks MR/NMR
01.	Access to Building:			
A	Road width	6.0 meter	6.0 meter	MR
B	Gate width	N/A	N/A	N/A
C	Width of internal road	N/A	N/A	N/A
02.	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases			
a	Upper floor	02 nos.	02 nos.	MR
C	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor	1.5m each	Provided	MR
C	Basement	N/A	N/A	N/A
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	02 nos	02 nos	MR
E	Width of corridor	1.5m	1.6m	MR
F	Door size	1m (for class room)	1.0m. (for class room)	MR
03.	Compartmentation:			
A	Fire check door	N/A	N/A	N/A
B	Sealing of electrical shafts	N/A	N/A	N/A
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A
04.	Smoke Management System:			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
05.	Fire Extinguisher:			
A	Total numbers	10 nos.	10 nos.	MR
B	Types	ABC & CO ₂	ABC & CO ₂	MR
C	ISI marking	ISI Marked	Provided	MR

06. First-Aid-Hose Reel:				
A	Total numbers of each floor	1 No.	1 No.	MR
B	Length of hose reel hose	30m	30m	MR
C	Nozzle diameter	5mm	5mm	MR
07. Automatic Fire Detection and Alarming System:				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
08.	MOEFA:	N/A	N/A	N/A
09	Public Address System:	N/A	N/A	N/A
10.	Automatic Sprinkler System:			
A	Basement	N/A	Provided	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants:			
A	Size of riser/down-comer	N/A	100mm	N/A
B	Number of hydrants per floor	N/A	02 nos	N/A
C	Hose box	N/A	02 nos	N/A
12.	Yard Hydrants:			
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
13.	Pumping Arrangements:			
1	Ground level			
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
2	Terrace Level			
A	Discharge of pump	450 LPM	Provided	MR
B	Head of the pump	40m	Provided	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting:			
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	10,000 liters	10,000 liters	MR

15.	Exit Signage:	Required	Provided	MR
16.	Provision of Lifts:			
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17.	Standby Power Supply:	N/A	N/A	N/A
18.	Refuge Area:			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19.	Fire Control Room:			
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20.	Special Fire Protection systems for protection of special Risks, if any:	NA	N/A	N/A

The fire protection system was randomly checked and tested and was found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards on prevention and fire safety measures as required under the Rules the Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2022/SZ/1229 dated 11/11/2022, under the rule of the Delhi Fire Service Rules, 2010 is recommended.

13/11/2026

Signature of the Inspecting Officer
 Name: - Yashwant Singh Meen
 Designation: - ADO/BCP

DO/SD

14/11/26

A.K. MALIK

15/11/26

P10