



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F6/DFS/MS/GH/SZ/2026/ 128

Dated: 29/06/2026

FIRE SAFETY CERTIFICATE

Certified that the Institute for Socialist Education, 9/1, Secular House opp JNU, East Gate, Aruna Asaf Ali Road, New Delhi-110067, comprised of A-Block (Ground plus 01 Upper floor) & B-Block (Basement, Ground plus Three Upper Floors), having given an affidavit/undertaking that 2nd & 3rd floor of b-block is not in use & locked since 2013 on dated 15/06/2026 (places at C-44-45), was issued FSC vide letter no-F6/DFS/MS/2022/SZ/01 dated-02/01/2023. The premises was re-inspected by the officer concerned of this department on 15/06/2026 in the presence of Sh. Sumit Diwedi and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and the premises fit for occupancy Class (Educational Group-B) with effect from 29/06/2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions mentioned below.

Issued on 29/06/2026 at New Delhi by


(A.K. Malik)
Chief Fire Officer

Copy to:

1. The Commissioner MCD, Civic Centre, Minto Road, New Delhi- 110002.- to ensure the occupancy as detailed above & deviation in construction if any.
2. The authorized signatory, Plot Institute for Socialist Education, 9/1, Secular House opp JNU, East Gate, Aruna Asaf Ali Road, New Delhi-110067. (Online ID No. 52026052803232)

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management/occupier.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction, electrical, lift, setback area etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. All the means of escape such as exit, corridor, passageway etc. shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.
9. Basement shall be used as per building bylaws strictly.

INSPECTION REPORT

1. Name & address of the building	Institute for Socialist Education, 9/1, Secular House opp JNU, East Gate, Aruna Asaf Ali Road, New Delhi-110067.
2. Type of Occupancy	Group-B "Educational". Comprised of A-Block (Ground plus 01 Upper floor) & B-Block (Basement, Ground plus Three Upper Floors)
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/2022/SZ/01 dated- 02/01/2023
5. Fire Safety directives letter No	F6/DFS/MS/2007/3796 dated-24/12/2007(12 Bare min point)
6. Date of inspection	15/06/2026
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Mr. Sumit Diwedi
9. Year of Construction	1970 (as per previous inspection report dtd.-24/12/2022)
10. Applicant's letter No.	Online ID NO- 52026052803232

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Required	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02 nos. each blk	Provided	MR
	• Basements	02 nos.	Provided	MR
	b. Width of staircases			
	• Upper Floors	1.25m/0.90m	G+3-1.35m & 1.06m G+01- 1.50m & 1.06m	MR (old case)
	• Basements	1.25m/0.90m	1.45m & 1.20 m	MR (old case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01 each blk	Provided	MR
	e. Width of Corridor	1.50m	Provided	MR
	f. Door Size	01m	Provided	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR

5	Fire Extinguishers			
	• Total numbers	32 nos.	32 nos.	MR
	• Types	CO ₂ , ABC type	ABC & CO ₂	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor/block	02 nos.	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	05mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of main panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	02 nos.	Provided	MR
	• Hose Box	02 nos.	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main Pump	1600 LPM	Provided	MR
	➤ Head of Main pump	40m	Provided	MR
	➤ Number of main pumps	01 nos.	Provided	MR
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	900 LPM	Provided	MR
	➤ Head of the pump	30 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

N/13

14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	1,00,000 ltrs.	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20,000ltrs	Provided	MR
15	Exit Signage.			
		Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift Lobby	NA	NA	NA
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply			
		Required	Provided	MR
18	Refuge Area.			
	• Total Area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	Required	Provided	MR
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	Required	Provided	MR
	• Building Floor Plans	Required	Provided	MR
20	Special Fire Protection Systems for Protection of special Risks, if any:			
		NA	NA	NA

Note:- The owner/occupier submitted an affidavit/undertaking that 2nd & 3rd floor of b-block is not in use & locked since 2013, on dated 15/06/2026 (places at C-44-45).

The fire protection systems provided in the building were checked randomly and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC issued vide letter no F6/DFS/MS/2022/SZ/01 dated- 02/01/2023, renewal under the rule 37 of the Delhi Fire Service rules 2010 is recommended. Accordingly, DFA is put up for approval and signatures please.

[Signature]
19/6/24
Sarabjeet Singh
ADO (Malviya Nagar)

(DO/SD)

[Signature]
20/6/24
Ravinder Singh

[Signature]
20/6/24

[Signature]
20/6/24
A.K. MALIK

[Signature]
A.K. MALIK

CFO to Issue.

[Signature]
22/6/24

[Signature]
CFO(SZ)