



75
Azadi Ka
Amrit Mahotsav

cl37

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/CGHS/2025/SZ/ 961

Dated: 06/06/2025

To

Sh. Vijay Sharma (President),
M/s Insurance Employees CGHS Ltd,
(Krishna Kunj), Plot No. 14, Sector-07,
Dwarka, New Delhi-110075


Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Insurance Employees CGHS Ltd (Krishna Kunj), located at Plot No. 14, Sector-07, Dwarka, New Delhi-110075

Sir,

This has a reference to your letter No Nil dated 29/04/2025, received through outdoor diary No.1117 dated 29/04/2025. In this connection, it is to inform you that the premise was visited by the officer concerned of this department on 21/05/2025 in your presence to verify the compliance of the shortcomings issued by this office vide letter No. F6/DFS/MS/CGHS/2024/SZ/279 dated 22/05/2024 and observed that the shortcomings are still not fully complied.

In view of the above, application for renewal of fire safety certificate cannot be considered at this stage. You are requested to comply with all the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,


5/6/2025

(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Deputy Director (Bldg.), DDA, Vikas Sadan, INA, New Delhi-110023

G-33
C/32

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001

NO. F6/DFS/MS/CGHS/SZ/2024/ 279

DATED: 22/05/2024

To,

The President,
Insurance Employee CGHS Ltd.
Plot No 04, Sector – 7, Dwarka, New Delhi.

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o Insurance Employee CGHS Ltd. Located at Plot No 14, Sector – 7, Dwarka, New Delhi.

Sir,

This is in reference to your letter No. nil dated 15/04/2024 on the subject cited above. In this connection it is to inform to you that the above said premises was inspected by the officer concerned of this department on 16/05/2024 in the presence of Mr. Bimlesh Kumar from fire safety point of view.

During the course of inspection followings shortcoming are observed:-

1. The internal road around the building found encroached / blocked.
2. Hose reel hose and hydrants found nonfunctional.
3. Fire pumps at terrace level found nonfunctional & not on auto mode.
4. Exit signage's found removed at some places.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter. The occupancy of the building premises without valid Fire Safety Certificate is on the risk and responsibility of the management committee.

Yours faithfully,


(Atul Garg)
(Director)
Delhi Fire Service

Copy to:-

1. The Joint Director, DDA, Vikas Sadan, INA, New Delhi.