



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



42

No. F.6/DFS/MS/CGHS/2025/SZ/ 376

Dated: 11 / 08 / 2025

To

The President,
Insurance Employees CGHS Ltd,
(Krishna Kunj), Plot No. 14, Sector-07,
Dwarka, New Delhi-110075

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Insurance Employees CGHS Ltd (Krishna Kunj), located at Plot No. 14, Sector-07, Dwarka, New Delhi-110075

Sir,

This has a reference to your letter No Nil dated 16/06/2025, received in this department vide outdoor diary No. 3152 dated 27/06/2025. In this connection, it is to inform you that the premise was re-visited by the officer concerned of this department on 15/07/2025 to verify the compliance of shortcomings issued by this office vide letter No. F6/DFS/MS/CGHS/2024/SZ/279 dated 22/05/2024, in the presence of Mr. Vimlesh Kumar (Guard) and the status of shortcomings observed is as below.

S. No.	Shortcomings issued	Present Status
1.	The internal road around the buildings found encroached/blocked.	Not complied
2.	Hose-reel hose and hydrants found non-functional.	Complied
3.	Fire pumps at terrace level found non-functional.	Complied
4.	Exit signage's found removed at some places	Complied

In view of the above, application for renewal of fire safety certificate cannot be considered at this stage. You are requested to comply with the left-over shortcoming under intimation to this department for further action in the matter.

Yours faithfully,


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Deputy Director (Bldg.), DDA, Vikas Sadan, INA, New Delhi-110023