



d/41

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/GH/NDZ/2026/ 371

Dated: - 24/04/2026

To,
The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Iqbal Guest House located at 1193, Churiwalan, Jama Masjid, Delhi - 110006.

Sir,

Please refer your online application ID No. 2026032403472 dated on 24/03/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 14/04/2026 in the presence of Sh. Babulal (Manager) and following shortcomings were observed: -

1. Fire Extinguisher cylinders found outdated.
2. First-aid Hose reel provided but found non-functional.
3. Automatic operation of fire pump was not provided.

Keeping in view of the above shortcomings, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands rejected. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,


23/4/26
(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service
del

Copy to: -

1. The Manager, M/s Iqbal Guest House located at 1193, Churiwalan, Jama Masjid, Delhi - 110006.