



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/School/NDZ/2025/ 193

Dated: 04/04/2025

To,

The Principal,
Iqra Public School,
B-305, Street No.6, 25 ft. Road,
Nehru Vihar, Delhi-110094.

Subject: - Regarding grant of Fire Safety Certificate in r/o Iqra Public School located at B-305, Street No.6, 25 ft. Road, Nehru Vihar, Delhi-110094

Sir,

This has a reference to your letter diary no. 12668 Dated 19/02//2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 26/03/2025 in the presence of Mr. Mohd. Farhat Ansar (Principal) and observed that building comprised of ground plus three upper floors.

Following shortcomings were observed during time of inspection:

1. Two staircase of width 1.10 mtr. & 0.70 mtr. provided against requirement of 1.50 mtr. each.
2. Width of corridor 1.0 mtr. provided against requirement of 1.50 mtr.
3. Fire extinguisher not provided.
4. First-Aid-Hose Reel not provided.
5. Fire pump of 450 LPM not provided.
6. Over head water storage tank of 10,000 litres. not provided.
7. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Director of Education, MCD Civic Centre, Jawahar Lal Nehru Marg, New Delhi.