




No. F6/DFS/MS/School/SZ/2025/ 1345

Dated: 26/ 11 /2025

**FIRE SAFETY CERTIFICATE**

Certified that the Ishani Sarvodaya Kanya Vidyalaya located at G – Block, Saket, New Delhi - 110030 (School - ID 1923036 & 1923068) comprised of ground plus three upper floors owned / occupied by Directorate of Education, Govt of NCT of Delhi was issued earlier FSC vide letter No. F6/DFS/MS/School/2022/SZ/223 dated 02/03/2022. The school building was re-inspected by the officer concerned of this department on 13/11/2025 in presence of Dr. Harita Arora (Principal) and overseed that all the Fire Prevention and Fire Safety arrangement provided found in good working condition. The premises have therefore deemed rule 33 of Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class "Educational Building" (Group-B) with effect from 26/ 11 /2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 26/11/2025 at New Delhi by.

  
(A.K. Malik)  
Dy. Chief Fire Officer  
Delhi Fire Service  
o/c @

**Copy to: -**

1. The Director of Education, Govt of NCT of Delhi, Old Secretariat, Delhi – 110054.
2. The Assistant Engineer (E) Edu. Maint.Sub-div-M1, PWD, Hauz Khas, New Delhi - 110054

**Conditions for the validity of Fire Safety Certificate**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).



# INSPECTION REPORT

1	Name & address of the building	Ishani Sarvodaya Kanya Vidyalaya located at G - Block, Saket, New Delhi - 110030 (School - ID 1923036 & 1923068)		
2	Building is comprised of	Ground plus three upper floors		
3	Type of occupancy	Educational Building (Group -B)		
4	Type of case	Renewal Case		
5	Details of previous FSC	F6/DFS/MS/School/2022/SZ/223 dated 02/03/2022		
6	Fire safety directives letter no.	Nil		
7	Date of inspection	13/11/2025		
8	Name of the inspecting officers	Yashwant Singh Meena, ADO/BCP		
9	Name of the designation of officer from the building side	Dr. Harita Arora (Principal)		
10	Year of construction	2018-19		
11	Applicant's letter no.	Outdoor Diary No. 7182 dated 16/10/2025		
S. No	Minimum standard of fire prevention and fire safety U/R 33	UBBL 2016 Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to Building:</b>			
	A Road width	Required	9.0 meters.	MR
	B Gate width	N/A	N/A	N/A
	C Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type and Arrangement of Exits:</b>			
	A Number of staircases			
	a Upper floor	02 Nos.	03 Nos.	MR
	b Basement	N/A	N/A	N/A
	B Width of staircases			
	a Upper floor	1.50 meter	1.50 meter each	MR
	b Basement	N/A	N/A	N/A
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	N/A	N/A	N/A
	E Width of corridor	1.50 meter	1.50 meter	MR
	F Door size	1.0 meters.	1.0 meters	MR
3	<b>Compartmentation:</b>			
	A Fire check door	NA	NA	NA
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management System:</b>			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A

W ✓

5.	Fire Extinguisher:				
	A	Total numbers	10 No's.	12 No's.	MR
	B	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	C	ISI marking	ISI mark	Provided	MR
6	First-Aid-Hose Reel:				
	A	Total numbers of each floor	02 at each	03 no's Provided	MR
	B	Length of hose reel hose	30 m	Provided	MR
	C	Nozzle diameter	05 mm	Provided	MR
7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
8	MOEFA:		N/A	N/A	N/A
9	Public Address System:		N/A	N/A	N/A
10	Automatic Sprinkler System:				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:				
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12	Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump	2 x 450 LPM	Provided	MR
	B	Head of the pump	40 m	Provided	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting:				
	A	Underground tank capacity	N/A	N/A	N/A
	B	Draw-off connection	N/A	N/A	N/A
	C	Fire service inlet	N/A	N/A	N/A
	D	Access to tank	N/A	N/A	N/A
	E	Overhead tank capacity	10,000 liters	Provided	MR



15	Exit Signage:	Required	Provided	MR
16	Provision of Lifts:			
	A Pressurization of lift shaft	N/A	N/A	N/A
	B Pressurization of lift lobby	N/A	N/A	N/A
	C Communication in lift car	N/A	N/A	N/A
	D Firemen's grounding switch	N/A	N/A	N/A
	E Lift signage	N/A	N/A	N/A
17	Standby Power Supply:	N/A	N/A	N/A
18	Refuge Area:			
	A Total area	N/A	N/A	N/A
	B Location	N/A	N/A	N/A
19	Fire Control Room:			
	A Detector system panel	N/A	N/A	N/A
	B Flow switch panel	N/A	N/A	N/A
	C PA system panel	N/A	N/A	N/A
	D Battery backup	N/A	N/A	N/A
	E Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:			

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections. The shortcomings issued by this department vide letter no. F6/DFS/MS/School/2025/SZ/633 dated 11/08/2025 has been rectified

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter F6/DFS/MS/School/2022/SZ/223 dated 02/03/2022, renewal under Rule 35(6) of the Delhi Fire Service rules 2010, is recommended.

14/11/2025

Signature of the Inspecting Officer  
Name Yashwant Singh Meena  
Designation ADO/BCP

D.O/SD

14/11/25  
Ravinder Singh  
Dy. Secy (S2)

17/11/25  
A.K. MALIK

Principal Director

My. Cfo to Secy.

My. Cfo (S2)

20/11/25  
A.K. MALIK  
ADO/BCP

21/11/25  
Ravinder Singh  
P.S.D