

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/School/2025/SZ/633

Dated: 11/08/2025

To

The Principal
M/s Ishani, Sarvodaya Kanya Vidyalaya,
G-block, Saket, New Delhi-110030

Sub: Regarding renewal of FSC in r/o Ishani, Sarvodaya Kanya Vidyalaya, G-Block, Saket, New Delhi-110030 (ID -1923036)

Sir,

This has reference to your letter no. ISKV/2025-23/78 dated 23/07/2025 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 31.07.2025 in the presence of Dr. Harita Arora (Principal) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. First aid hose reel found non functional.
2. Terrace level Fire Pump capacity of 450 LPM found non functional.
3. Exit Signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,


9/8/2025

**(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE**

du