

c/30

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE

NEW DELHI-110 001.

No. F.6/DFS/MS/School/2025/SZ/ 1074

Dated: 26/08/2025

FIRE SAFETY CERTIFICATE

Certified that the building of Issa Public School located at Village Issa Pur, New Delhi- 110073, comprised of ground floor only, owned/occupied by Issa Public School, was issued FSC by this department vide letter No. F.6/DFS/MS/School/2022/SZ/713 dated 27.06.2022. The School building was re- inspected by the officer concerned of this department on dated 07.08.2025, in the presence of Sh. Tariff Singh (Manager) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/premises (for ground floor only) is fit for occupancy class "Educational Building" w.e.f. 26/08/2025 for a period of three years, subject to compliance of the conditions printed as below.

Issued on 26/08/2025 at New Delhi by.


(Virendra Singh)
Chief Fire Officer

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
2. The Manager, Issa Public School located at Village Issa Pur, New Delhi- 110073.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/LL

INSPECTION REPORT

- | | | |
|-------------------------------------|---|--|
| 1. Name & address of the building | : | Issa Public School, Village Issa Pur, New Delhi-110073 |
| 2. Building comprised of | : | Ground floor only |
| 3. Type of Occupancy | : | Educational |
| 4. Type of Case | : | Renewal |
| 5. Details of Previous NOC | : | F.6/DFS/MS/School/2022/SZ/713 dated 27.06.2022 |
| 6. Fire Safety directives letter No | : | N/A |
| 7. Date of inspection | : | 07.08.2025 |
| 8. Name of Inspecting Officer | : | A.D.O. R.K. Yadav (JKP) |
| 9. Name and designation of officers | : | |
| From the building side | : | Sh. Tariff Singh (Manager) |
| 10. Year of Construction | : | 2002 |
| 11. Applicant's letter No. | : | Nil dated 24.06.2025 |

Sr. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible N/A N/A	03 mtrs 1.3 mtrs. N/A	M/R (Motorable road is 50 mtrs away) N/A N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	N/A	N/A	Ground Floor Only
	• Basements	N/A	N/A	No basement
	b. Width of staircases			
	• Upper Floor	N/A	N/A	Ground Floor Only
	• Basements	N/A	N/A	No basement
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1.0 m	1.05m	M/R Students are less than 45 in each class.
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	N/A N/A	N/A N/A	No basement Ground Floor Only
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	02 no's ABC/CO2 type ISI marked	04 no's Provided Provided ISI marked	M/R M/R M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A

7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15.	Exit Signage.	N/A	N/A	N/A
16.	Provision of Lifts.			
		No Lift		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A

N/18

18.	Refuge Area.			
	> Total Area	N/A	N/A	N/A
	> Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F.6/DFS/MS/School/2022/SZ/713 dated 27.06.2022 is recommended to be renewed in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education.

Signature of Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (JKP)

DO (South West)

[Signature]
19/8/25

CFO/*[Signature]*
19/8/2025

Principal Director

CFO to Gen.

[Signature]
19/08/25

CFO/*[Signature]*
20/8/2025

DO (SW)
ADO (JKP)

P70