

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No.F.6/DFS/MS/BP/2023/ 194

Dated: 11/09/2023

To,

The Executive Engineer (Bldg.) HQ,
Municipal Corporation of Delhi,
8th floor, Minto Road, New Delhi-110002.

Sub: Clearance from fire safety point of view r/o IT enabled service industry similar to business building, Plot no - 71/5, Najafgarh Road Industrial Area, Delhi.

Sir,

Please refer your online request ID No.-10116913 dated 02/09/2023, on the subject cited above. In this connection, it is to inform you that the building plans were scrutinized from fire safety point of view and observed that there is a proposal of new construction of building at Plot no - 71/5, Najafgarh Road Industrial Area, Delhi.

Following shortcomings are observed:

1. Travel distance on some floors is not meeting the requirement as per clause 7.8.1 & table 8.2 of UBBL-2016.
2. Openable panel/windows shall be provided on external wall of each floor.

Accordingly, the case is hereby rejected.

Yours faithfully,



(Atul Garg)
Director

011-23414000

OK CS