



75
Azadi Ka
Amrit Mahotsav

C-66

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/ 227

Dated: 16/04/2025

To

The Principal,
ITBP Public School,
Sector-16 B, Dwarka,
New Delhi-110078

Sub: Renewal of Fire Safety Certificate in r/o ITBP Public School located at Sector-16 B, Dwarka, New Delhi.

Sir,

Please refer to your letter No. ITBPPS/DFS/2024-25/503 dated 17/02/2025 received through outdoor diary no.14358 dated 11/03, on the subject above. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department on dated 27/03/2025 in presence of Sh. Surjan Singh (Principal) from fire safety point of view and the following shortcomings are observed.

1. Fire Check Doors (FCDs) Closer found damage/non-functional.
2. MOEFA found non-functional
3. Hose Reels & Hydrants system found non-functional.
4. Sprinkler system in basement found non-functional
5. All the fire pumps at terrace level found non-functional.
6. Lift Signage & Exit signage's found removed at some places.

In view of the above, renewal of fire safety certificate cannot be considered at this stage. The occupancy of the building/premises in the absence of valid fire safety certificate/requisite fire safety measures, shall be at the risk and liability of school management.

Yours faithfully,


(ATUL GARG)
DIRECTOR
Ph. 011-23414000
JLC RK

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054