



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/WZ/2025/ 156

Dated: 09/04/2025

To,

Mr. Tripathi,  
M/s IVT Co-operative Group Housing Society Ltd.,  
(Savera Apartments),  
Sector-13, Plot No.5, Rohini,  
Delhi-110085.

**Sub:** Issue of FSC in r/o M/s IVT Co-operative Group Housing Society Ltd. Savera Apartments),  
Sector-13, Plot No.5, Rohini, Delhi-110085.

Sir,

Kindly reference to online e-mail dated 16.12.2024, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **02.04.2025**, in presence of **Mr. Pankaj Gupta** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. 6 meter road all around the building at corner side reduced due to construction of temple.
2. Auto starting/Manual stopping system of pumps not functional.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:  
[http://www.delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/)  
[http://www.delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms)

Yours faithfully

(Atul Garg)  
DIRECTOR

Ph; 011-23414000

Atul Garg