



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/WZ/2025/ 396

Dated: 20/08/2025

To,

The Secretary,  
M/s IVT Co-operative Group Housing Society Ltd.,  
(Savera Apartments),  
Sector-13, Plot No.5, Rohini,  
Delhi-110085.

**Sub:** Renewal of FSC in r/o M/s IVT Co-operative Group Housing Society Ltd. (Savera Apartments), Sector-13, Plot No.5, Rohini, Delhi-110085.

Sir,

Kindly refer to letter received in this department through outdoor diary no. 3679 dated 11.07.2025 on the subject cited above. In this connection it is to inform you that the shortcoming already issued by this department letter of even No. 156 dated 09.04.2025 (Copy enclosed) & the status of shortcoming is as follows;

Kindly refer to letter received in this department through outdoor diary no. 3679 dated 11.07.2025 on the subject cited above. In this connection it is to inform you that the building was visited by officer of this department on dated 01.08.2025, in presence of **Mr. Pankaj Gupta** & it has been observed that the **shortcoming already issued** by this department letter of even No. 156 dated 09.04.2025 (Copy enclosed) & the status of shortcoming is as follows;

1. 6 meter road all around the building at corner side reduced due to construction of temple.  
(Not Rectified)
2. Auto starting/Manual stopping system of pumps not functional. (Rectified)

Therefore, you are advised to submit compliance of all the shortcomings issued vide this department letter dated 09.04.2025 for further consideration in this matter.

Yours Faithfully

  
(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service

DL  
DL

