

e-20

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI

No. F6/DFS/MS/School/WZ/2025/ 867

Dated: 04/07/2025

FIRE SAFETY CERTIFICATE

Certified that the J.M. Memorial Public School, located at F-104, Sudershan Park, New Delhi-110015, is running at ground and first floor, in a building comprised of ground + 02 upper floors (second floor temporary shed), owned/occupier by J.M. Memorial Public School, was issued FSC vide letter No F6/MS/DFS/2006/1659 dated 19/07/2006. The premises was re-inspected by the officer concerned by this department on 17/06/2025 in the presence of Mrs. Rita (Principal) and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. That the building/premises have deemed complied with fire prevention and fire safety requirements in accordance DOE Circular 262-362 dated 17/01/2005 and the building/ premises is fit for occupancy class "Educational" (Group -B) (for ground and first floor only) with effect from ...04/07/2025 for a period of three years. Condition mentioned below.

Issued on ...04/07/2025 at New Delhi.

(Apul Garg)
Director

Delhi fire service

Copy to:

1. The Principal, J.M. Memorial Public School, located at F-104, Sudershan Park, New Delhi-110015.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.

Conditions for the validity of FSC:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. Owner/occupier has given an undertaking that not to use second floor (temporary shed), if is used for school activity FSC/NOC shall be null & void automatically.

INSPECTION REPORT

1.	Name & address of the building	J.M. Memorial Public School, located at F-104, Sudershan Park, New Delhi-110015.
2.	Type of Occupancy	Educational (Ground + 1 Upper Floor)
3.	Type of Case	Renewal
4.	Details of previous NOC	F6/MS/DFS/2006/3863 dated 29/12/2006
5.	Fire Safety directives letter No	DOE Circular 262-362 dated 17/01/2005
6.	Date of inspection	17/06/2025
7.	Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8.	Name and designation of officers from the building side	Mrs. Rita (Principal)
9.	Year of Construction	1972 (As per previous Inspection Report dated 09/03/2018)
10.	Applicant's letter No.	Outdoor dairy No. 14728 dated 20/03/2025.

The said school is running at ground and first floor, in a building comprised of ground + 02 upper floor (Second floor temporary Shed). was already issued FSC vide this department letter No. F6/MS/DFS/2006/1659 dated 19/07/2006, for ground and first floor only.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible Accessible NA	Provided Provided NA	MR MR NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	02	Provided	MR
	<ul style="list-style-type: none"> Upper Floors Basements 	NA	NA	NA
	b. Width of staircases	1.5m	1X0.88m, 1X0.98m	MR(old case)
	<ul style="list-style-type: none"> Upper Floors Basements 	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	<ul style="list-style-type: none"> Fire check door Pressurization 	NA	NA	NA
	d. No. of continuous staircases to terrace	1	Provided	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1m	1m	MR(old case)
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	NA NA	NA NA	NA NA
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	5 nos. CO ₂ , ABC type ISI marked	10 nos.Provided Provided Provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA NA NA	NA NA NA	NA NA NA

7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA

18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

NOTE: - Owner/occupier has submitted an undertaking that not to use second floor (temporary shed), if is used for school activity FSC/NOC shall be null & void automatically.

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/MS/DFS/2006/3863 dated 29/12/2006, renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

Q Y (RPW)

SP
19/6/2015

Signature of the Inspecting Officer
Sarabjeet Singh ADO (MN)

ADGM
12/6/2015

CFO
30/6/2015

Director
10/7/2015

ADGM

Sir, F T is put up for your kind perusal & signature
Director
10/7/2015

SP
03/7/2015