



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001




No. F6/DFS/MS/2026/School/ WZ/ 167

Dated: 12 / 10/2026

FIRE SAFETY CERTIFICATE

Certified that the J. S. International School located at Agar Nagar, Prem Nagar-III, Near Main, Mubarak Pur Road, Delhi-110086, comprised of Ground + First Floor owned/ occupied by J. S. International School was issued Fire Safety Certificated vide this office letter no. F6/DFS/MS/2022/WZ/School/830 dated 02/08/2022 for ground floor only. The premise was re-inspected by the officer concerned of this department on 26/08/2026 in the presence of Smt. Bhawna and observed that the management has running one more floor and building is now comprised of ground + first floors and all the fire prevention and fire safety arrangements as provided in the school building found in good working condition and that the premises fit for occupancy **Class "Group B Educational (School) For Ground + First Floors Only"** with effect from 12/10/2026..... for a period of three years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 12/10/2026 at New Delhi


(A.K. Malik)
Chief Fire Service
Delhi Fire Service
909

Copy to: -

1. The Dy. Director of Education, Zone- XIII, District North West- B (II), Sector-9, Rohini, Delhi – 110085.
2. The Manager, J. S. International School located at Agar Nagar, Prem Nagar-III, Near Main, Mubarak Pur Road, Delhi-110086.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the DFS portal along with a copy of this Certificate, **six months** prior to its expiry".

2/13

INSPECTION REPORT

1. Name & address of the building : J. S. International School Agar Nagar, Prem Nagar-III, Near Main Mubarak Pur Road, Delhi-110086.
2. Type of Occupancy : Education (School)
3. Type of Case : Add/Alt (New Case)
4. Composition of building : Ground + First Floor Only
5. Details of Previous NOC : F6/DFS/MS/2022/WZ/School/830 dated 02/08/2022 For Ground floor only
6. Fire Safety directives letter No : NBC Part-IV.
7. Date of inspection : 26/08/2026
8. Name of Inspecting Officer : ADO(Kirari)
9. Name and designation of officer
From the building side : Smt. Bhawna
10. Year of Construction : 2017 & 2018
11. Applicant's letter No. : Online DFS Portal Application No. 52026052303127

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	Road width	Accessible	Accessible	MR
	Gate width	4.50m	Accessible	MR
	Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	Upper Floors	02	03	MR
	Basements	NA	NA	NA
	b. Width of staircases			
	Upper Floor	1.5m	1.70m	MR
	Basements	NA	NA	NA
	c. Protection of exits			
	Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	Provided	MR
	e. Width of Corridor	1.50m	Provided	MR
	f. Door Size	1.20m	Provided	MR
3.	Compartmentation			
	Fire check door	NA	NA	NA
	Sealing of electrical shafts	NA	NA	NA
	Fire Rating of shaft door	NA	NA	NA
	Water Curtain	NA	NA	NA
	Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	Basements	NA	NA	NA
	Upper floors	Required	Natural Ventilation	MR
5.	Fire Extinguishers			
	Total numbers	10nos.	14nos.	MR
	Types	ABC/CO2	ABC-14	MR
	IS marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	Total numbers on each floor	01	Provided	MR
	Length of hose reel hose	30m	Provided	MR
	Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			

Cy


	- Type of detectors - Location of Main Panel - Location of Repeater Panel - Alternate source of power - Hooters' Location	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	- Basement - Ground & Upper Floors - Sprinkler above false ceiling	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants			
	- Size of riser/down-comer - Number of hydrants per floor - Hose Box	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	- Total number of hydrants - Hose Box	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements			
	- Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual Stopping ➤ Pump House Access	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	- Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump			
		450 LPM	Provided	MR
		40m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	- Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank - Overhead Tank capacity	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000 Ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	- Pressurization of Lift Shaft - Pressurization of Lift lobby - Communication In lift Car - Fireman's Grounding Switch - Lift Signage	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area ➤ Location	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room			
	Detector System Panel	NA	NA	NA
		NA	NA	NA

N/15

	- Flow Switch Panel - PA System Panel - Battery backup - Building Floor Plans	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection. The observations/ shortcomings issued and communicated vide this department letter of even no. 52026052303127 dated 12/06/2026 have been complied by the management.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended for Grant Fire Safety Certificate.

 08/09/2026


Signature of the Inspecting Officer

Name :-C.L. Meena

Designation:- ADO (Kirari)

Dr. Rajesh Kumar (DO/NW)


 19/9/2026



 21/09/2026

Chf (WZ)


Debabrata Mukherjee


 21/9/26
A.K. MALIK

Mr. Mr. when was the applⁿ received?
stis 12/8/26
May 2018

 26/9/26
A.K. MALIK

to Mr. Mr. Chf to Mr. Mr.
6/10

 7/10/26
A.K. MALIK



Comm -