

C/112

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**  
**NEW DELHI- 110 001**

No.F.6/DFS/MS/Hospital/2025/NDZ/ 558

Dated: 26/11/2025

To,

The Assistant Engineer (Elect.)  
Health Maintenance Electrical Sub-Division HE-II,  
Public Works Department (GNCTD),  
Jag Pravesh Chandra Hospital, Shastri Park,  
Delhi-110053

Subject: -Regarding renewal of Fire Safety Certificate in r/o Jag Pravesh Chandra Hospital, Shastri Park, East Delhi-110053.

Sir,

With reference to your letter no. 19(17)/A.E(E)/PWD/HMESD HE-2/2025-26/38 dated 12/11/2025 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 17/10/2025 in the presence of Sh. Anjan Biswas, A.E (Elect.). The hospital building comprised of basement, ground plus three upper floors. During the course of inspection following observations were made: -

1. The fire check door was found removed in one staircase having a width of 02 meters.

In view of the above, the building cannot be considered for renewal of Fire Safety Certificate at this stage. Therefore, you are requested to rectify the above-mentioned shortcomings under intimation to this office for further course of action.

Yours faithfully,



(Dr. S. K. TOMAR)

DY. CHIEF FIRE OFFICER (NDZ)

9/2. DELHI FIRE SERVICE

To: -

1. The Medical Superintendent, Jag Pravesh Chandra Hospital, Shastri Park, Delhi-110053
2. The Executive Engineer, Electrical Health Maint. Div. (East), B-221N, GTB Hospital Complex, Shahdara, Delhi-110095