



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/11/25
आजादी का
अमृत महोत्सव

319

No. F6/DFS/MS/School/SZ/2025/1303

Dated: 11 / 11 / 2025

FIRE SAFETY CERTIFICATE

Certified that Jain Girls Secondary School located at Green Park Extn. New Delhi New Delhi -110016 building comprised of Ground plus One upper floor only, owned / occupied by Jain Girls Secondary School was issued earlier FSC vide letter No. F6/DFS/MS/School/2022/SZ/990 dated 09/09/2025. Now, The said premise was re-inspected by officer concerned of this department on 03/11/2025 in presence of Mrs. Neerja Jain (Manager) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No 262-362 dated 17/01/2005 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "Educational Building Group-B" with effect from 11 / 11 / 2025 for a period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 11/11/2025 at New Delhi by.


(A.K. Malik)
Dy. Chief Fire Officer
Delhi Fire Service
o/c @

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
2. The Principal, Jain Girls Secondary School located at Green Park Extn. New Delhi-110016

Conditions for the validity of Fire Safety Certificate

1. The owner / occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

01.	Name & address of the building	Jain Girls Secondary School, Green Park Extn. New Delhi -110016.		
02.	Building is comprised of	Ground plus one upper floor		
03.	Type of occupancy	Educational Building (Group-B)		
04.	Type of case	Renewal		
05.	Details of previous FSC	F6/DFS/MS/School/2022/SZ/990 dated 09/09/2022		
06.	Fire safety directives letter no.	DOE Circular NO.262-362 dated 17/01/2005		
07.	Date of inspection	03/11/2025		
08.	Name of the inspecting officers	Yashwant Singh Meena, ADO (BCP)		
09.	Name of the designation of officer from the building side	Mrs. Neerja Jain (Manager)		
10.	Year of construction	2006		
11.	Applicant's letter no.	Outdoor dairy no. 6237 dated 22/09/2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Old NOC Requirement	Provided at site	Remarks MR/NMR
01.	Access to Building:			
	A Road width	6m	6m	MR
	B Gate width	N/A	N/A	N/A
	C Width of internal road	N/A	N/A	N/A
02.	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	02 nos.	01 & 01 Iron	MR
	C Basement	N/A	N/A	N/A
	B Width of staircases			
	a Upper floor	1.25 m	1.25 m & 0.91m	MR (old case)
	C Basement	N/A	N/A	N/A
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	N/A	N/A	N/A
	E Width of corridor	N/A	N/A	N/A
	F Door size	1.0 mtr.	Provided	MR
03.	Compartmentation:			
	A Fire check door	N/A	N/A	N/A
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
04.	Smoke Management System:			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A
05.	Fire Extinguisher:			
	A Total numbers	06 nos.	Provided	MR
	B Types	ABC/CO ₂	ABC/CO ₂	MR
	C ISI marking	ISI Marked	Provided	MR


06.	First-Aid-Hose Reel:			
A	Total numbers of each floor	N/A	N/A	N/A
B	Length of hose reel hose	N/A	N/A	N/A
C	Nozzle diameter	N/A	N/A	N/A
07.	Automatic Fire Detection and Alarming System:			
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
08.	MOEFA:			
09	Public Address System:			
10.	Automatic Sprinkler System:			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants:			
A	Size of riser/down-comer	N/A	N/A	N/A
B	Number of hydrants per floor	N/A	N/A	N/A
C	Hose box	N/A	N/A	N/A
12.	Yard Hydrants:			
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
13.	Pumping Arrangements:			
1	Ground level			
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
2	Terrace Level			
A	Discharge of pump	Booster pump	Provided	MR
B	Head of the pump		Provided	MR
C	Power supply	N/A	N/A	N/A
D	Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting:			
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	2500 ltrs	Provided	MR
15.	Exit Signage:			
		Required	Provided	MR

n/19

16.	Provision of Lifts:			
	A	Pressurization of lift shaft	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A
	C	Communication in lift car	N/A	N/A
	D	Firemen's grounding switch	N/A	N/A
	E	Lift signage	N/A	N/A
17.	Standby Power Supply:			
18.	Refuge Area:			
	A	Total area	N/A	N/A
	B	Location	N/A	N/A
19.	Fire Control Room:			
	A	Detector system panel	N/A	N/A
	B	Flow switch panel	N/A	N/A
	C	PA system panel	N/A	N/A
	D	Battery backup	N/A	N/A
	E	Building floor plans	N/A	N/A
20.	Special Fire Protection systems for protection of special Risks, if any:			
			NA	N/A


The fire protection system was randomly checked and tested and was found functional at the time of inspection.


Keeping in view of the deemed compliance of minimum standards on fire prevention and fire safety measures as required under the rules, the Fire Safety Certificate issued vide letter no F6/DFS/MS/School/2022/SZ/990 dated 09/09/2022, renewal under rule 37 of the Delhi Fire Service rules, 2010 is **recommended**.


 Signature of the Inspecting Officer
 Name: - Yashwant Singh Meena
 Designation: - ADO/BCP

DO/SD


 6/11/25
 Ravinder Singh

Dy. CFS (SZ)

 27/11/25
 A.K. MALIK
 Principal Director

Dy. CFS to Secy.

 07/11/25

Dy. CFS (SZ)

 27/11/25
 A.K. MALIK


 17/11/25
 Ravinder Singh