

C-7

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/NDZ/2025/ 654

Dated: 18/08/2025

To

The Principal
Jainson Public School,
C-12/139 Khajuri Colony, Delhi-110094.

Sub: Regarding Fire Safety Certificate in r/o Jainson Public School, C-12/139 Khajuri Colony, Delhi-110094.

Sir,

This has reference to your letter No. JPS/25/04/03 on the subject cited above. In this regard, it is to inform you that the premises was inspected by the officer concerned of this department on 25/07/2025 in the presence of Mrs. Shikha Jain (Principal) to ascertain the availability and operability of the fire prevention and fire safety measures and observed that at present building comprised of Ground plus three upper floors.

Following shortcomings were observed during the time of inspection:-

1. Hose reel hose not provided.
2. Fire Pump of capacity 450LPM not provided.
3. Overhead tank of capacity 10,000 ltr not provided.
4. Exit signage not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected under sub rule (3) of Rule 37 of DFS Rules-2010. The occupancy of the building/premises in absence of requisite fire safety arrangement shall be at the risk and liability of the management. The Statutory Authority may take suitable necessary action as deemed fit.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for issue of fire safety certificate under sub-rule (2) on Form "I" with compliance of above shortcomings. The web links for DFS Act-2007 / Rules 2010 & Form "I" are as under :

http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/Fire/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/Fire/Home/Forms

Yours faithfully


(VIRENDRA SINGH)
CHIEF FIRE OFFICER.

Copy to:-

1. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053.