



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/Hotel/SZ/2026/ 696

Dated: 17/07/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
9th floor, Civic Centre, Minto Road,
New Delhi-110002.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Jakk Residency (A Unit of Jakk India) located at Plot No 4, Kh No. 52/18/2, Bhawani Kunj, Kishangarh, Mehrauli, New Delhi-70.


Sir,

With reference to the elt.mcdonline application no. 2026060608325 on the subject cited above, it is informed that the said Guest House was inspected by officer concerned of this department on 04/07/2026 in the presence of Mr. Kulwendra singh (Owner) and following shortcomings were observed.

1. Staircase width is 1.20 m & 1.41 m provided against the requirement of clear width is 1.50 meters each.
2. Fire Check Door (FCD) has not been provided.
3. Corridor width 1.80 m has not been provided.
4. Lift signages has not been provided.

In view of above shortcomings, the application of renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(A. K. Malik)
Chief Fire Officer

Copy to:-

1. The Owner/Occupier/Manager, Jakk Residency (A Unit of Jakk India) located at Plot No 4, Kh No. 52/18/2, Bhawani Kunj, Kishangarh, Mehrauli, New Delhi-70.