

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110001**

No.F.6/DFS/MS/EH/2025/SZ/230

Dated...11/06/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Eating House in the Name & Style **M/s Kaleva Foods** situated at GF & FF, Kh. No 354, Sant Nagar, Shakur basti, Rani Bagh, Pitampura, Delhi 110034 comprised of Ground & One upper floor was issued Fire Safety Certificate by this department vide letter no. F.6/DFS/MS/EH/WZ/2022/264 dated 16/09/2022. The restaurant premise was re-inspected by the officer concerned of this department on 06/06/2025 in the presence of Mr. Sukesh of the restaurant and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building"** Restaurant at Ground & First floor only) and **validity upto 31/03/2028** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 11/06/2025 at New Delhi by

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. The Addl. Commissioner of Police, Lic/Branch, 1<sup>st</sup> Floor PS Defence Colony, New Delhi 110049 (Ref. MCD Portal No. 2025050107685 dated 10/05/2025)

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."



# INSPECTION REPORT



1	Name & Address of the Building	M/s Kaleva Foods situated at GF & FF Kh. No 354, Sant Nagar, Shakur basti, Rani Bagh, Pitampura, Delhi 110034		
2	Type of Occupancy	Restaurant at Ground and First Floor only		
3	Building Comprised of	Ground & First Floor only		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/EH/WZ/2022/264 dated 16/09/2022		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	06/06/2025		
8	Name of the Inspecting Officers	ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Sukesh		
10	Year of construction	2000		
11	Applicant letter No.	MCD Portal No. 2025050107685 dated 10/05/2025		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	Provided	MR
	• Gate width	4.50 mtr	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 Nos	03 Nos	MR
	➤ Basement floor.	N/A	N/A	N/A
	b) Width of Staircase			
	➤ Upper floors	1.50 mtr each	2m, 1.50m & 0.99m	MR
	➤ Basement floor	N/A	N/A	N/A
	c) Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	Required	03 No	MR
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	2 x 1.50 mtr	2.10m & 1.55m	MR
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.			
	• Basement	30 ACPH	N/A	N/A
	• Upper floors	12 ACPH	Natural Ventilation	MR
5	Fire Extinguishers.			
	• Total numbers	08 Nos	10 Nos	MR
	• Types	ABC/CO <sub>2</sub>	ABC- & CO <sub>2</sub> -	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			



	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System	N/A	N/A	N/A
10	Automatic Sprinkler System	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground floor.</li> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
11	Internal Hydrants.	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Size of Riser/Down-comer</li> <li>Number of Hydrant per floor</li> <li>Hose box.</li> </ul>	Required	100 mm	MR
12	Yard Hydrants.	Required	One	MR
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> <li>Hose box.</li> </ul>	Required	One	MR
		N/A	N/A	N/A
13	Pumping arrangements.	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump.</li> <li>Head of main pump.</li> <li>Number of main pumps.</li> <li>Jockey Pump output.</li> <li>Jockey Pump head.</li> <li>Standby Pump output.</li> <li>Standby Pump head.</li> <li>Auto Starting/Manual Stopping.</li> <li>Pump house access.</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Terrace Level</li> <li>Discharge of pump.</li> <li>Head of pump.</li> <li>Power supply.</li> <li>Auto starting of pump.</li> </ul>	450 LPM	450 LPM	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> <li>Underground tank capacity.</li> <li>Draw-off connection.</li> <li>Fire Service Inlet.</li> <li>Access to tank.</li> <li>Overhead tank capacity.</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
15	Exit Signage.	20,000 Ltrs	20,000 ltr	MR
16	Provision of Lifts.	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> <li>Pressurization of lift lobby.</li> <li>Communication in lift car.</li> <li>Fireman's switch.</li> <li>Lift signage.</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> <li>Total area</li> <li>Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A

19	Fire Control Room.	N/A		
	<ul style="list-style-type: none"> <li>Detector system panel.</li> <li>Flow switch panel.</li> <li>PA system panel.</li> <li>Battery backup.</li> <li>Building floor plan.</li> </ul>	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F.6/DFS/MS/EH/WZ/2022/264 dated 16/09/2022, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Design: ADO (BCP)

DCFO (WZ)

DCFO/...700...  
Dated...16/10/22

Director

Director

As approved, F.T. letter is put up for your signature P

U/Ploded  
12/11/25