

C/42

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/Community Hall/2025/ 67

Dated: 17/02/2025

To,

Mr. Lalit Shukla (Authorized Signatory),
Jan Kalyan Manoranjan Samiti (Regd.),
OFC-1 & Pocket-1, Sector-13, Rohini,
Delhi-110085.

Sub: Issue of Fire Safety Certificate (FSC) in r/o Jan Kalyan Manoranjan Samiti (REGD.)
Community Hall located at OFC-1 & Pocket-1, Sector-13, Rohini, Delhi-110085.

Sir,

Kindly reference to online e-mail dated 10.12.2024, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 03.02.2025, in presence of Mr. Lalit Shukla to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. FCD found removed at some places.
2. Tin shed and temporary construction found affecting smoke ventilation of build and basement smoke management system found non functional.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules
[/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

Yours faithfully

(Anil Garg)
DIRECTOR
Ph: 011-23414000
OK
CM