

C-180

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.


No. F.6/DFS/MS/Club/2025/SZ/286

Dated: 04/06/2025

FIRE SAFETY CERTIFICATE

Certified that the **Janak Puri Club** located at Plot No. 17, Janak Puri District Centre Complex, Janak Puri, New Delhi-110058, comprised of Two Basements, Ground Plus three upper Floors (2nd Basement is sealed). The first basement is used as parking, ground floor having reception, dining halls, kitchen, bar & offices, first floor having party hall, kitchen, card room, carom room, second floor having halls and third floor having 07 guest rooms **owned/occupied by Janak Puri Club**, was issued fire Safety Certificate by this department vide letter No. F.6/DFS/MS/2022/SZ/CLUB/183 dated 25.04.2022. The Club building was re-inspected by the officers concerned of this department on dated 27.05.2025 in the presence of Sh. Om Prakash (General Secretary) and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules 2010 and that the building/premises **(Except second basement)** is fit for occupancy class Group D "Assembly building" w.e.f. 04/06/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed under.

Issued on 04/06/2025 at New Delhi by.


(Virendra Singh)
Chief Fire Officer
Delhi Fire Services
vc

Copy to: -

1. The Manager, Janak Puri Club located at Plot No. 17, Janak Puri District Centre Complex, Janak Puri, New Delhi-110058.
2. Executive Engineer (Bldg.), MCD, West Zone, Dr. Sahib Singh Varma Nigam Bhawan, Second Floor, Shivaji Enclave, New Delhi-110027, for information regarding use of basement.

Conditions for validity of Fire Safety Certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. Basement shall be used as per the building bye laws.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
10. In case of usage of second basement the FSC should stand be null and void.

INSPECTION REPORT

1. Name & address of the building : Janak Puri Club, Plot No.-17, Janak Puri District Centre Complex, Janak Puri, New Delhi-110058
2. Building comprised of : Two basements, ground plus three upper floors but second basement is sealed with brick wall.
3. Type of Occupancy : Group 'D' Assembly Building.
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/2022/SZ/CLUB/183 dated 25.04.2022
6. Fire Safety directives letter No : F6/MS/DFS/BP/2006/513 dated 01.03.2006
7. Date of inspection : 27.05.2025
8. Name of Inspecting Officer : A.D.O. R.K. Yadav (JKP)
9. Name and designation of officers
From the building side : Sh. Om Prakash (General Secretary)
10. Year of Construction : 2006-2013
11. Applicant's letter No. : Nil, dated 26.05.2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	12 m 05 m N/A	Provided Provided N/A	M/R M/R N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors 	GF to FF 04 no.'s & FF to SF 03 no.'s & SF to TF 02 no.'s	Provided	M/R
	<ul style="list-style-type: none"> Basements 	Basement to GF 04 no.'s & ramp	Provided	M/R
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor 	1.50 m	GF to FF 2.35, 1.50 (03 no.'s), FF to SF 1.50 (03 no.'s) & SF to TF 1.50 & 1.22 m	M/R
	<ul style="list-style-type: none"> Basements 	1.50 m	1.50 (04 no.'s) & ramp	M/R
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door 	Required	Provided	M/R
	<ul style="list-style-type: none"> Pressurization 	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	Required	Provided	M/R
	e. Width of Corridor	1.50 m	2.70m	M/R
	f. Door Size	1.50 m in hall (03 no.'s) & 2.0 m in restaurant	2.30, 1.70, 1.65 m in hall & 2.0m in restaurant	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door 	Required	Provided	M/R
	<ul style="list-style-type: none"> Sealing of electrical shafts 	Required	Provided	M/R
	<ul style="list-style-type: none"> Fire Rating of shaft door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Water Curtain 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fire Dampers 	N/A	N/A	N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements 	Required	Exhaust fans Provided	M/R
	<ul style="list-style-type: none"> Upper floors 	Required	Provided	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	25 no.'s	Provided	M/R
	<ul style="list-style-type: none"> Types 	W/CO ₂ / CO ₂ type	Provided	M/R
	<ul style="list-style-type: none"> IS marking 	ISI marked	ISI marked	M/R

N/53

6.	First-Aid Hose Reels			M/R
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Two 30 m 5 mm	Provided Provided Provided	M/R M/R M/R
7.	Automatic fire detection and alarming system			M/R
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Required Required Required Required Required	Provided Ground Floor First Floor Provided At Exits	M/R M/R M/R M/R M/R
8.	MOEFA	Required	Provided	M/R
9.	Public Address System	Required	provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	Required Required N/A	Provided Provided N/A	M/R M/R N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	Required Two GF, FF & SF/One TF Required	Provided Provided Provided	M/R M/R M/R
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	Seven Seven	Provided Provided	M/R M/R
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	2280 LPM 60 mtrs. One Required 60 mtrs. 2280 LPM 60 mtrs. Required	Provided Provided Provided Provided Provided Provided Provided Provided	M/R M/R M/R M/R M/R M/R M/R M/R
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	Required 900 LPM 40 mtrs. Required Required	Provided Provided Provided Provided Provided	M/R M/R M/R M/R M/R
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	50000 Ltrs Required Required Required 10,000 Ltrs.	Provided Provided Provided Provided Provided	M/R M/R M/R M/R M/R
15.	Exit Signage.	Required	Provided	M/R

N/54

16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	Required	Provided	M/R
	• Lift Signage	Required	Provided	M/R
17.	Standby power supply	Required	Provided	M/R
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. Carbon Monoxide Detectors are provided in guest rooms.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/2022/SZ/CLUB/183 dated 25.04.2022, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

R.K. Yadav
 Signature of Inspecting Officer
 Name: - R.K. Yadav
 Designation: - ADO (JKP)

~~DO (SW)~~

29/5/22
29/5/22
30/5/2025

~~Director~~

~~DO (SW)~~

2/6
2/6
Asst (fire)

P00