



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

266
75
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/SZ/2025/44/450

Dated:- 20/11/2025

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi -110002.

Sub.: Regarding renewal of Fire Safety Certificate in r/o M/s Jannat Guest House, located at 2646-2647, GF, FF and SF Gali Qasim Janwali, Main Bazar, Ballimaran, Delhi-110006.

Sir,

This has reference to online application no. 2025102414345 dated 23/10/2025 on the subject cited above. In this connection, it is to inform you that the above said building was re-inspected by the officer concerned of this department on 11/11/2025 in the presence of Sh. Wasim Javed (Manager) to check the compliance of shortcomings issued by this department vide letter no. F6/MS/DFS/NDZ/2020/651 dated 20/03/2020.

During inspection, it have been observed that the shortcomings issued by this department vide above said letter has not been rectified yet.

In view of the above, the application for renewal of Fire Safety Certificate cannot be considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


19/11/25

Dr. S.K. Tomar
Dy. Chief Fire Officer (NDZ)

Copy to:-

1. The Authorized Signatory, M/s Jannat Guest House, located at 2646-26-47, GF, FF and SF Gali Qasim Janwali, Main Bazar, Ballimaran, Delhi-110006.

AC
19/11/25

c/60

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/MS/DFS/NDZ/2019/651

Dated: 20/03/2020

To

M/s Jannat Guest House,
2649-47, Main Bazar, Ballimaran, Delhi-06

Sub: - Regarding issue of "Fire Safety Certificate" in r/o M/s Jannat Guest House, 2649-47, Main Bazar, Ballimaran, Delhi-06.

Sir,

This has reference to letter dated 21.01.2020 on the subject cited above. In this connection this is to inform you that the site has been inspected by the officer concerned of this department on 14.03.2020 in the presence of manager and it was observed that the shortcomings already communicated by this department vide letter no. F6/DFS/MS/NDZ/2018/3392 dated 07.08.2017, 07.02.2018 & 03.05.2019 has not been rectified till date. Some more shortcomings were noticed further during inspection which are as under:-

1. Staircase locked at 4th floor.
2. Fire tank not segregated.

The management is requested to rectify the shortcomings at the earliest. In view of above, Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,



(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service
Tel: 011-23414262

etc 

Copy to:-

The Joint Commissioner of Police: Licensing,
1st Floor, Police Station Defence Colony, New Delhi