

c/06



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F.6/DFS/MS/School/SZ/2025/ 161

Dated: 17/03/2025

To
The Principal,
M/s Janta Public School,
H-398/17, Gulab Farm House,
Sangam Vihar, New Delhi-62.

Sub: Regarding renewal of Fire Safety Certificate in respect of M/s Janta Public School located at H-398/17, Gulab Farm House, Sangam Vihar, New Delhi-62.

Sir,

This has reference to letter bearing outdoor diary no. 12241 dated 07.02.2025 on the subject cited above. In this context it is informed that the said school building was inspected by the officer concerned of this department on 11.03.2025 in the presence of Mrs. Neha (Manager) and it was observed that school building is comprised of Ground + 01 upper floors. During the inspection following shortcomings were observed:-

1. Alternate staircase of minimum width of 0.75 meters must be provided.
2. Hose reel found removed at each floor level.
3. Fire pump found removed at terrace.
4. Fire tank having capacity of 2,500 liters (exclusively for firefighting) found removed.
5. Exit signages found removed.

In view of above shortcomings, the application renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Gang)
Director

Delhi Fire Service

Copy to:-

1. The Directorate of Education, MCD, Dr. S.P.M Civic Centre, Minto Road, New Delhi-110002.