



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/SZ/2025/266

Dated:- 02/06/2025

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi -110002.

Sub:- Regarding renewal of Fire Safety Certificate in respect of M/s Jashn's Inn Guest House, Plot No. 50, Pocket-II, Jasola Vihar, New Delhi-110025

Sir,

This has reference to online application no. 2025041506416 dated 02/05/2025 on the subject cited above. In this connection, it is to inform you that the said building was re-inspected by the officer concerned of this department on 27/05/2025 in the presence of Sh. Sahab Ram Sharma (Manager) to check the compliance of shortcomings issued by this department vide letter no. F6/DFS/MS/GH/SZ/2024/249 dated 17/05/2024.

During inspection, it has been observed that the shortcomings issued by this department vide above said letter has not been rectified yet.

In view of the above, the application for renewal of Fire Safety Certificate cannot be considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Virender Singh)
Chief Fire Officer

Copy to:-

1. The Authorized Signatory, M/s Jashn's Inn Guest House, Plot No. 50, Pocket-II, Jasola Vihar, New Delhi-110025.



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5
आज़ादी का
अमृत महोत्सव
C-64

No. F6/DFS/MS/GH/SZ/2024/ 249

Dated: 17/05/2024

To

The Joint Commissioner of Police,
Office of Joint Commissioner of Police: Licensing,
1st Floor, P. S Defence Colony, New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o **M/s Jashn's Inn Guest House** located at **Plot No. 50, Pocket-II, Jasola Vihar, New Delhi-25.**

Sir,

With reference to the MHA online application no. 2024041605260 on the subject cited above, it is informed that the said building was inspected by officer concerned of this department on 10.05.2024 in the presence of Mr. Vikas (Manager) and it was observed that the building is comprised of Basement (vacant) + Ground + 03 upper floors & Temporary construction on terrace floor. During the inspection following shortcomings were observed:

1. Temporary construction on terrace must be removed.
2. Hose reel found non functional.
3. Fire pump found non functional.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

14/5/24