

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/ **1087**

Dated: **02/08/2025**

FIRE SAFETY CERTIFICATE

Certified that the **J.D Tytlar School**, located at DDA Flat, Munirka, New Delhi-110067 comprised of Ground plus two upper floors owned/occupied by J.D Tytlar School, was issued FSC by this department vide letter No. F.6/DFS/MS/School/2022/SZ/912 dated 22-08-2022. The premise was re-inspected by the officer concerned of this department on 19/08/2025 in the presence of Mr. Anuj Kumar (Account) and found that school have deemed complied with the fire prevention and fire safety arrangements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "**Educational Building, Group-B**" with effect from **02/08/2025** for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on **02/08/2025** at New Delhi by

 **21/8/2025**

(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

1. The Principal, J.D Tytlar School, located at DDA Flat, Munirka, New Delhi-110067.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi -54

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This certificate cannot be treated as regularization of unauthorized construction, if any.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	J. D Tytlar School, DDA Flat, Munirka, New Delhi-110067		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground + Two upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2022/SZ/912 dated 22-08-2022		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	19-08-2025		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Anuj Kumar (Account)		
10	Year of construction	2006		
11	Applicant letter No.	Email dated 08/08/2025		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirements Old NOC	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width 	Required	Approachable	MR
	<ul style="list-style-type: none"> Gate width 	Required	4.50m	MR
	<ul style="list-style-type: none"> Width of internal road 	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 Nos	02 Nos	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.5 mtr	1.50 mtr each	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	One	one	MR
	e) Width of corridor	Required	2 mtr	MR
	f) Door size	Required	1 mtr	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Sealing of electrical shafts. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fire rating of shaft door. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Water curtain 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fire dampers. 	-NA-	-NA-	-NA-
4	Smoke Management system.			
	<ul style="list-style-type: none"> Basement 	30 ACPH	-NA-	-NA-
	<ul style="list-style-type: none"> Upper floors 	12 ACPH	-NA-	-NA-
5	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers 	ISI marked	15 Nos	MR
	<ul style="list-style-type: none"> Types 		ABC & CO ₂	MR
	<ul style="list-style-type: none"> ISI Marking 		Provided	MR
6	First Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor. 	02 No each Hose Reel	Provided	MR
	<ul style="list-style-type: none"> Length of hose-reel hose. 		30m	MR
	<ul style="list-style-type: none"> Nozzle Diameter 		5mm	MR
7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Location of Main Panel 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Location of Repeater Panel 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Alternate source of power 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Hooter's location 	-NA-	-NA-	-NA-
8	MOEFA	-NA-	-NA-	-NA-

9	Public Address System	-NA-	-NA-	-NA-
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump house access. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	450 LPM	450 LPM	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		10,000 Ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17	Standby Power Supply	-NA-	-NA-	-NA-
18	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19	Fire Control Room.			
	<ul style="list-style-type: none"> Detector system panel. Flow switch panel. PA system panel. Battery backup. Building floor plan. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any.	-NA-		-NA-

The Fire protection systems provided in the building/premise were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/School/2022/SZ/912 dated 22-08-2022, **renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.**

Accordingly, DFA is put up for approval and signature please.

[Signature]
22/08/2025

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

DO (South)

[Signature]
20/8/25

cto | *[Signature]*
23/01/2025

Principal Director

cto to Smt.

[Signature]
28/08/25

cto | *[Signature]*
29/8/2025

ADO (BCP)

F.T. letter is put up for your
signature P

[Signature]
11/9/2025

cto/HA | *[Signature]*
21/9/2025

[Signature]