

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

c/37

No.F.6/DFS/MS/School/2025/ 777

Dated: 12 / 06 /2025

FIRE SAFETY CERTIFICATE

Certified that the Jeewan Jyoti Sr. Sec. School located at Ch. Hukam Singh, Street No.-3, Sadatpur, Extn. Delhi-94, building comprised of Ground plus two upper Floors but school is running only on Ground plus two upper floors owned / occupied by Jeewan Jyoti Sr. Sec. School was issued FSC vide letter No. F6/DFS/MS/School/2022/NDZ/401 dated 8/4/22. The school building was re-inspected by the officer concerned of this department on 03/06/2025 in presence of Sh. Rakesh Bansel (Manager) and observed that all the Fire Prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular no. 262-362 dated 17/01/2005 and that the building / premises is fit for occupancy class "Educational" (Group-B) with effect from 12 / 06 /2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 12/06/2025 at New Delhi by.

Virendera Singh
10/6/2025
(VIRENDERA SINGH)
CHIEF FIRE OFFICER.

Copy to :-

1. Manager, Jeewan Jyoti Sr. Sec. School, Ch. Hukam Singh, Street No.-3, Sadatpur, Extn. Delhi-94.
2. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053.

Conditions for the validity of Fire Safety Certificate:

1. Fire Safety Certificate is valid Ground & Two Upper Floors only.
2. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1.	Name & address of the building	Jeewan Jyoti Sr. Sec. School, Ch. Hukam Singh, Street No.-3, Sadatpur, Extn. Delhi-94.		
2.	Type of Occupancy	Educational		
3.	Building Comprised of	Ground plus 2 upper floors		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F6/DFS/MS/School/2022/NDZ/401 dt. 8/4/22		
6.	Fire Safety directives Letter No	Cir. 262-362 dated 17/01/2005		
7.	Date of Inspection	05.06.2025		
8.	Name of the Inspecting Officer	D.O. (East)		
9.	Name and Designation of Officer from the building side	Sh. Rakesh Bansal (Manager)		
10.	Year of Construction	1993		
11.	Applicant's letter No.	JJSSS-535 dated 09/04/2025		
S. No	Minimum standards on fire prevention and fire safety U/R 33	Requirements As per rule 35(6)	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6m	10m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	2	MR
	• Basements	NA	NA	NA
		NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50m	1.30 mtrs & 1.25 mtr.	MR (Old Case)
	• Basements	NA	NA	NA
		NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	2	MR
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	1m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	6	9	MR
	• Types	ABC /CO ₂	Provided	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	2	2	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	5 mm	5 mm	MR

7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	220 LPM	450 LPM	MR
	➤ Head of the pump	40 mtr	40 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	3,000 ltr	4,500 ltr	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA


N/15

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Note:- 1. The Principal of the school has submitted an undertaking placed at C-34 that 3 rooms being constructed on terrace will not be used for school purpose. Fire Safety Certificate is sought for Ground & two upper floors only.
2. Fire protection and exit requirement are provided as per initial inspection (Noting N/01)


The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/2022/NDZ/401 dated 8/4/22 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.


 Signature of the Inspecting Officer
 Name : Ashok Kumar Jaiswal
 Designation: D.O. (East)


Dy. C.F.O. (NDZ)


 06/06/25


 6/6/2025

DO (East)

As Approved, F.T. is put up for sign. pl.


 10/6/2025


 09/06/25

MS cell