

c 41

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/2025/SZ/College/128

Dated: 29/10/2025

To,

Prof. Sandra Joseph (Principal)  
Jesus and Mary College,  
Chanakyapuri, New Delhi - 110021.

Sub: Regarding renewal of Fire Safety Certificate in r/o Jesus and Mary College, Chanakyapuri, New Delhi - 110021.

Sir,

This has reference to letter Ref. No. JMC/PO/FS/ComplianceReport(cl)/2025 dated 19/08/2025 received through Outdoor Diary No. 314 dated 20/08/2025. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department on dated 06/10/2025 from fire and life safety point of view. Prof. Sr. Molly K.A (Officiating Principal) & Mr. Ram Kailash (Care-taker) was present at the time of inspection. During the course of inspection, the shortcomings observed are as below.

1. Wooden material shall be painted with fire retardant paint.
2. Fire/Smoke check doors not provided in MP Hall.
3. Computer laboratory/classes are running in basement of the multipurpose hall which is to be approved by the building sanctioning/licensing/local authority.
4. Exit signages are found removed at some places.
5. Lift Signages found Removed.

In view of the above, renewal of fire safety certificate is rejected. You are directed to rectify the shortcomings mentioned above without further delay. The assembly building remains unsafe from fire safety point of view and it shall be at the risk & liability of the management committee until the compliance.

Yours faithfully,



A.K. Malik  
Dy. Chief Fire Officer (SD)  
Delhi Fire Service

Copy to: -

1. The Chief Architect, Department of Architecture & Environments, N.D.M.C., Palika Kenra, New Delhi - 110001.